

May 22

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	03/05/22	R.M.C मध्ये पुस्तक काढणे					
		कॉफी मिळाले		Prepared by	-	-	-
		2) Health post मध्ये पुस्तक		Mr. Patwardhan			
		कॉफी काढणे मिळाले					
		3) कॉलेज मधली सर्व खांद्या		Done by mohesh			
		शिफ्टिंग केटिंग करणे मिळाले		manojkumar. ekrao			
		4) खांद्या हेव्हाइंगसाठी लाकडी		शिवकुमार शिंदे	-	-	-
		टोकरे मिळाले		कॉफी काढणे मिळाले			
		5) अस्पताल		All carpenter work done by			
		कार्यवाही		Shivkumar material used by site office			

PRINCIPAL



HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

  
DEAN

Boys Hostel  
Shelam  
Building

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	10/05/22	9) 210th room का दरवाजा खोलने में दिक्कत	Swapnil				
		10) Room No - 215 का दरवाजा खोलने में दिक्कत	Kshirsagar	All carpentry work done by			
		11) Room No - 214 का दरवाजा खोलने में दिक्कत	<del>Swapnil</del> Dishant	Mr. Mahajan Sir & Shivkumar Baram			
		12) Room No - 206 का दरवाजा खोलने में दिक्कत		Material used for this		in side	
		13) Room No - 217 का दरवाजा खोलने में दिक्कत		3 days			
		14) Room No - 209 का दरवाजा खोलने में दिक्कत					
		15) Room No - 210 का दरवाजा खोलने में दिक्कत					
		16) Room No - 301 का दरवाजा खोलने में दिक्कत					

DEAN



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	10/01/22	Room NO-115 मसुदा कायम करी गिरी.	Swapnil	All work done by under Permission			
		Room No. 116 मसुदा कायम करी गिरी.	Kshirsagar	of Mahajan sir		done maintenance	
		* गिरी मसुदा करी गिरी. * गलियारी मसुदा करी गिरी.		Done by Shivkumar's team.			
		Room No. 117 मसुदा करी गिरी.		Material used for this from site			
		Room No. 221 मसुदा कायम करी गिरी.		given			
		Room No. 202. मसुदा कायम करी गिरी.		Kshirsagar			
		* मसुदा करी गिरी.					
		Room No. 47 Gally मसुदा करी गिरी.					
		Room No. 216 मसुदा कायम करी गिरी.					
		Room No. 203 मसुदा कायम करी गिरी.					

DEAN



14/01/22

HEAD OF THE DEPARTMENT DEAN

**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE**

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	10/05/22	Room No.110 मीत गुणवत्ता सीटें करी गरी.	Swarnil Kshirsagar	All work done by under permission Ashri Mahajan sir &			
		Room No.111 मीत गुणवत्ता सीटें करी गरी.		work Done by Shrikumar Sharma			
		Room No.112 मीत गुणवत्ता सीटें करी गरी.					
		मीत गुणवत्ता मीत गुणवत्ता सीटें करी गरी.					
		Room No.115 मीत गुणवत्ता सीटें करी गरी.					

DEAN



HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	10/05/2022	Room No.107 मीत द्यावा शाही काही मीत काढाय मीत.					
		Room No.108 मीत मीत द्यावा मी शाही काही द्यावा आहे.					
		बायकम मीत मीत शाही, बाहेरील काही मीत. काढाय मीत काढाय					
		Room No.109 मीत मीत काढाय काही मीत. मीत द्यावा मीत					
		मीत काही मीत. बायकम मीत शाही बाहेरील					
		काही मीत.					

DEAN



Handwritten signature and date 14/6/22

HEAD OF THE DEPARTMENT  
DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	12/05/2022	ADR, Patient HOD of 411/11/12 of 2022 अनुसंधान प्रयोगशाला.	Swarnil K. Shirogye <i>(Signature)</i> 12/5					
		HOD of 310/10/2022 :- अतिरिक्त दोस्त प्रयोगशाला.			All work is done by under Permission in shri Mahajan sir			
		Clinical Lab HOD of 219/2/2022 प्रयोगशाला.			work done by Shivkumar Sharma			
		* Physiology HOD :- अतिरिक्त प्रयोगशाला 24/2/2022						
		* PSM :- 117 Member :- अतिरिक्त 24/2/2022 प्रयोगशाला.						
		116 Member अतिरिक्त प्रयोगशाला.						
		114 - 11 - 11 -						

PRINCIPAL




HEAD OF THE DEPARTMENT

*(Signature)*  
14/6/22

*(Signature)*  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	12/05/2022	IHC Lab Pathology cupboard	Swapnil Kshirsagar	work done by Shivkumar			
		Paack. 50 nos polish done.		Sharma tw + persons			
		मॉड्यूल 4 मॉड्यूल 25 टॉप					
		मॉड्यूल 4 मॉड्यूल 16 टॉप					
	13/05/22	Anatomy museum Formilungar	Swapnil Kshirsagar				
		उपकरण 990311 क्लॉथ					
		α 9 सुविधा 1115 मॉड्यूल Formalinee मॉड्यूल					
	28/05/22	Anatomy D. freeze not working. Twp problems	Swapnil Kshirsagar	Freeze shut. work done by pitpal sharma	Fan is short	Replaced New	
			28/5/22	Remain hiteon to mone		Ren	

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	12/5/22	Certain Rod Fitting	<i>Rajhisaga</i>	Repaired by			
		Reqd for Anatomy museum		Rajkumar Sharma			
		Artist & Modular Room					
		Certain Rod Fitting Reqd		<i>सर्व सर्व कामे शिवागुणर मेरजे</i>			
		and Exhaust fan Crag		<i>खाली सेल हावलाती उद्वेगन</i>			
		fitting by Ply wood.		<i>डोर कडा हिली</i>			
		Main door hand fitting		<i>Rajhisaga</i>			
		Asst. Professor. पत्रिका व ऑफिस स्टोअर Office :- पत्रिका व ऑफिस स्टोअर.					
		52 Number Hall व ऑफिस स्टोअर ऑफिस स्टोअर.					
		Common toilet :- 2 व ऑफिस स्टोअर ऑफिस स्टोअर.					

PRINCIPAL





HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
05/05/22	05/05/22	संग्रह कक्षा मध्ये किट वापरणाऱ्या वेडि लाका (24/10/22)	श्रीम. शिवाजी श्रीम. शिवाजी	विद्यार्थ्यांसाठी माहिती देणे व वेडि वापरणे थांबवणे	-	-	-
	10/05/22	Anatomy museum मधील वेडि व इतर विद्यार्थ्यांसाठी वेडि F.M.C. museum मधील वेडि आणि इतर वेडि (4 NOS)	श्रीम. शिवाजी	prepair by mangesh mahadi	-	-	-
		Patho museum मधील वेडि इतर विद्यार्थ्यांसाठी (4 NOS)	श्रीम. शिवाजी	श्रीम. शिवाजी	-	-	-
		Biochemistry मध्ये वेडि आणि इतर	श्रीम. शिवाजी	श्रीम. शिवाजी (Mr. Ronald Pravin)	-	-	-
	18/05/22	व वेडि वापरणे थांबवणे व वेडि वापरणे थांबवणे	श्रीम. शिवाजी	sumukha ent.	-	-	-
		वापरणे थांबवणे आणि इतर	श्रीम. शिवाजी	Done by mangesh mahadi	-	-	-
		माहिती देणे	श्रीम. शिवाजी	Done by mangesh mahadi	-	-	-

DEAN



HEAD OF THE DEPARTMENT

DEAN

**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE**  
**KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606**  
**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
		Thelam Building		Pappu kumar			
				had Replained			
				all work on			
				4/1/2022 to			
				9/1/2022			
				x Pappu kumar			

DEAN



HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	20/05/2022	Histopathology Lab (HIO) MCB Trip- 8 switches not working.	<del>Sushil Kshirsagar</del> 28/07/22	Repaired by Mene electrician on 28/5/22	—	—	—
2)		Histo Lab :- 36 wt. Tube Band, 28W Tube Band.	} <del>Sushil Kshirsagar</del>	Repaired by Mene 23/5/22			
3)		Office :- 36W Tube on.					
		Passage :- 28W Tube not working.					
4)		Clinical Pathology Lab :- 2 Switch not working	<del>Sushil Kshirsagar</del>	Repaired by Dadekar Electrician			

DEAN



*(Handwritten Signature)*

HEAD OF THE DEPARTMENT  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

DEAN

STAMP

HEAD OF THE DEPARTMENT

दि. 22/05/22 दुपारी 3 ते 12/05/22 पर्यंत

शिवकुमार रामा ह्यांच्या कोठा साठसांवी

खातीला पुरवस्तो ची कामे करून दिली.

\* डोकल मॅन्डिंग - 1) वाढीला भिंगीवर एव.

2) येथे डू-हिलर पार्किंग करु नये हा बोर्ड बसवून

दिला.

अ. क्रम नं. 207 - मुख्य दरवाजाची कडी सुकून देवी.

207 - कपाच्या दरवाजा सुकून देवा.

207 - छात्रकम या दरवाजाची कडी सुकून देवी.

204: आरसा बसवला.

205. कडी कोयडा क रुम. नं. 102 कडी कोयडा

208 दरवाजाची कडी 10) कडी कोयडा, 304

कडी कोयडा, 309 कडी कोयडा 304 #

दरवाजाची कडी क कपाच्या सुकून देवा.

313 - कडी कोयडा. सुकून देवा.

\* मेडीकल कॉलेज.

\* सामकोबायलांगी ऑफीस कपाच्या कापु फुड्या येगी लावली ALP sheet बसवून मिळाले.

\* ब्लॉक बोर्ड शिफ्ट करून दिले.

\* कॉलेज मधील प्रजेक Lab हेत save व्हेरिफाय हा AP size चे बोर्ड लावून दिले.

\* APR 9 टॉयल मधील कडी कोयडा सुकून देवा  
HOD Room मधील Pedestral Handle सुकून देवा.

Clinical Lab मधील Tower Bolt सुकून देवा.

Physiology HOD Blending B.Patti बसवली  
PSM Room No. 107 5 Blending Patti बसवली

114 व 116 रुम मधील कडी कोयडा सुकून देवा.

Anatomy museum मधील 2 व मॉडेल व Modular Room मधील पदद्याचे रिस बसवून देवाले जिनेरून निवडले जाणे.

Anat. museum चा मुख्य दरवाजाची कडी सुकून देवा मिळाली.



DEAN

B.K.L. Wairavkar Rural Medical College  
Akkasanwadi, Post Saverde  
Tal. Chiplun, Dist. Ratnagiri

Ass. Prof. मीरडोल Lock कुठरा करण मिळाले -  
Office पुरेदार चे Lock कुठरा करण मिळाले  
52 एराजाचे लडी व कुठरा करण दिली.  
South Block Common Toilets लडी कोमंडा  
कुठरा केले. IHC Lab

\* IHC Lab (Pathology Dept) मधील  
Slide cupboard (50 slides capacity)  
रेंदा हा कुठरा कुठरा करण दिले.

Lecture Hall NO. 4 मधील 23 नंग  
बॅनेस. Screw fitting केले (कुठरा  
C Bag हेव्यासाठी केलेले Ply fit केले)

3 1/2 दिवस 2 मागसे

*Kshibagar*  
12/5/22 Swapnil  
Kshibagar



Pending

\* राहिलेले कामे  
1) फाभर सिलेंडर बसविणे  
2) बाँइज म लॉस्टेल बेतम मधील विद्यार्थी  
स्कुटीवर गेल असल्याने उ खोल्यांची  
कुठराची कामे बाकी आहेत.

वेतनी व विदेशा इमारतीच्या गॅर्योचे देवाडा  
कुठरा करायची आहेत.


North Block Ground Floor Common  
Toilet कायना (Ladies) देवाना बसवणे आहे

*Kshibagar*  
12/5/22  
Swapnil Kshibagar.

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
		Student Riding Hall-1	 30/08/22	Repaired by	RMC	28 wt - Tube Rod - 5m	
	30/08/22	5 nos 28 wt not working		Jitendra Gogav	008/22	36 wt - clock	
		1 fan not working		S Neethuram		1 nos	
		36 wt Tube not work		Sable on		1 Fan	
		10 switch 28 wt		14/10/2022		10 Switch New	
		Library passage - 28 wt				28 wt - 1	
		36 wt Tube not work				Tube Rod	
		Switch Not working - 1				36 wt clock Switch - 1	
		4) Librarian Room - 2 Tube				28 wt 2	
		28 wt 4 switch not work				NOJ - 1 Switch	

PRINCIPAL





HEAD OF THE DEPARTMENT




DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
		1) Gents & Ladies Toilet		Repaired by		5 wt - 3 Nos Led Tube		
	30/08/22	Tube Not working		Jitender Gajjar		10 wt - 1 N		
		2) 5/11 - Tube Not work		S Nathuram				
		3) 41041211 Cooler New tube fitting		Sabale. on	15/10/2022		10 wt	
		4) Issue counter - 2 switch & 5 Tube Not work		<del>S. Chikara</del>	<del>14/08/22</del>		2-Switch 10 wt 5 New Tube fitting	
		5) Passage - <del>28 wt</del> LED Tube no work			<del>14/10/22</del>		10 wt New feet	
		6) Central passage 36 wt Tube Not work				36 wt Tube Rod - 1 N		

PRINCIPAL




STAMP

HEAD OF THE DEPARTMENT



DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

Library

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	30/01/22	Issue common passage		Repaired by		10 wt Tube	
		35 wt LED Tube not working		Jitender Deyar		New fitting	
				S. Naathuram			
2)		Main entry passage	<i>[Signature]</i>	Sabale an		5 wt square box	
		12 wt square box not working		15/10/2022		New fitting	
3)		staff riding Hall 250.		<i>[Signature]</i>		25.0 tube	
		not tube working		<i>[Signature]</i>		Hall.	
4)		Issue cotter computer				3112.1191 cotter	
		switch board digspmp				3112.1191 cotter	

PRINCIPAL

*[Signature]*



*[Signature]*


HEAD OF THE DEPARTMENT

*[Signature]*  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
5)	30/6/2022	Staff Reading Hall 28.00 Tube not working 2 NOS		Repaired by Jitender Gaur & plathumun	2	28.00 tube		
6)		parking. CFL not working					28.00 tube	
7)		Student Reading Hall I fan not working			15/10/2022		fitting 2 NOS	
8)		Student Reading Hall II fan not working			15/10/2022		3 fan	

PRINCIPAL




STAMP

HEAD OF THE DEPARTMENT



DEAN



**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE**  
**KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606**  
**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	30/03/22	lecture Hall No.3 36.w. tube not working for 3	[Signature]	Repaired by Jitender Gagar S. Nathuram Sakale on 17/10/2022		2 choke tube Pool.		
27		lecture Hall No.4. new fitting & fan not working		stabile.		10w. Led. Light 5 Nos switch 2 etc.		
37		conferas room 3 tube not working.		[Signature]			36.w. choke 1 5.w. new Tube fitting 2001.	
47		lecture Hall No.2 36.w tube not working					1 36.w. choke	

PRINCIPAL  
[Signature]





[Signature] HEAD OF THE DEPARTMENT

[Signature]  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD


SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
5)	30/08/22	Pyasche 36-w. Not working		Repaired by		10w tube		
				Jitender Geyar			new fitting	
6)		Room No 35 Hall of Host of 5 m/c			2 Aluthuram Sabale on 17/10/2022		1 Fan	
7)		Room No 42 Hall of Host of 5 m/c		Sabale 		1 Fan		

PRINCIPAL




STAMP

HEAD OF THE DEPARTMENT





DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

Vidisha.

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
①	30/08/22	Porking. 3G.W.tube not working.		Repaired by Jitender Rajur & Nathuram Subale on 17/10/2022 		3G.W tube part 02 Nos new tube new fittings	

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL



STAMP

HEAD OF THE DEPARTMENT

  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
9	20/08/22	Boys Hostel अंतर्गत ROOM NO 116 & 312 दरवाजा व खोखोटा वीस वीस मिटे.		Repaired by Jitender Caggar & Nathuram Sabale on 14/10/2022 <del>Sabale.</del>			2 Fan
10		Boys Hostel अंतर्गत ROOM NO 110 अंतर्गत दरवाजा व खोखोटा वीस वीस मिटे.		Repaired by Jitender Caggar & Nathuram Sabale on 14/10/2022 <del>Sabale.</del>			1 Fan

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR .NO	DATE	NC DISCRIPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

  
DEAN

Anatomy

August. 2022  
General maintenance


## B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	18/08/22	Departmental offices		Replaced by T03	22.	36 wt tube	—
		1) Corridor. Tube	<i>Fisharage</i>	Tube set, (36 wt,		set 2 Nos	
		2) Assi. prott office	19/8/22	28 wt. 9) and		5-8 wt tube	
		3 - Demo Room		28 wt. Tube Rod		set 1 No tube	
		4) Tublight not working		by Nathuram Subcon 08/8/22		Rod 1	
2.	22/6/22	Ground floor Common		1 36 wt tube	22	36 wt tube	
		Toilet & Gents - tube		rod repaired		for Gents &	
		Not working	<i>Fisharage</i>	by Subc & Mene		28 wt tube	
		Ladies toilet tubelights	22/8/22	on 30/8/22		3 nos for	
		Not working				Ladies.	

PRINCIPAL


 23.9.22


STAMP


 HEAD OF THE DEPARTMENT


 DEAN

 Department of Anatomy  
 B.K.L. Walawalkar Rural Medical College  
 Kasarwadi, Post Sawarde,  
 Tal Chiplun, Dist Ratnagiri,  
 Maharashtra - 415606.

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

  
DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri

August PSM

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
<del>10/8/22</del>								
01	10/08/22	Asistao proff 2 tubes Not working.	} Ashinge 10/8/22	Replaced New tube light, Rods and holders by mene electrician and save on 30/08/22.	22	28W 530 22		
		Dept. Offices corridor 2 tube lights					28W 530W1	
		Room No. 118, 36 Demo Room holder No broken					36W1 Holder	
		6 PSM Lab. Passage tube Not working					Replaced New chake	

PRINCIPAL

*[Signature]*  
23.9.22



HEAD OF THE DEPARTMENT

*[Signature]*

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR .NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri

Pathology

August 22

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1.	14/8/22	Common toilet first floor	Swapnil Rishiraj	Replaced tube	22	28 W	
		Greets toilet tube lights	Rishiraj	tube light fixed		tube rsl.	
		Not working		by Manoj Sable			
				on 30/08/22			
2.	14/8/22	Cytopathology lab,	Rishiraj	28 Wt 1, 36 Wt 1	22	28 Wt tube	
		tube lights Not working		on @ 30/08/22		1 No 36 W	
				Manoj Sable		tube 1 NW	

PRINCIPAL

*[Signature]*  
23.9.22



HEAD OF THE DEPARTMENT

*[Signature]*  
23

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR .NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*  
DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagin

## B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE August

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
01	01/8/22	Autoclave Linkage & coil not working.	<i>[Signature]</i>	Repaired by Mauli Enterprises Sufessed by shri mahajan slr on 08/8/22	—	—	—
02	11/8/22	Autoclave coils not working	<i>[Signature]</i>	Replaced New coil by sawant Electrician	—	5000 W coil	—
03	15/8/22	Autoclave Not working and getting current	<i>[Signature]</i>	Replaced New coil & changing earthing wires by Kiran Patkar on 16/8/22	—	3 LANE coil.	—

PRINCIPAL

*[Signature]*  
23.9.22



HEAD OF THE DEPARTMENT

*[Signature]*  
Professor & Head  
Dept. of Microbiology  
B.K.L. Walawalkar Rural Medical College  
Sawarde, Ratnagiri



# September.

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
04	22/9/22	Autodave Room switch board was burned	<i>B. Shingde</i> 23/9/22 <i>Korachikar</i> madam	Replaced New board & charged all wiring in Autodave Room also shift one autodave in Washing Room with New wiring and New switches by <i>Kiran Patkar</i>	—	New switch board, msB, 3 wire.	—
		<i>Changes will done by shri Mahajan s/w Permission</i>					

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagin

September 2022

## B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

### FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
01.	16/09/22	College counicle hall tube light Not working	<i>[Signature]</i> 16/9/22	Replaced all New Round Led lights by Nathuram & Omkar <i>[Signature]</i> 16/9/22	In - stock	12 W Round 05 Nos	-
02.	16/09/22	Meeting table switches Not working	<i>[Signature]</i> 16/9/22	Repaired by Amit Bagave		Replace 2 mtr 2 core wire.	

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN



B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post. Sawarde  
Tal. Chiplun, Dist. Ratnagiri

September 2022

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
02	17/09/22	Surface light fittings, Exhaust Fan & Bathroom light Not Working in cafe building suits 201, 305, 306, Corridor forth floor lights, 6 tube surface light, Mirror tube light 206, 10 Conference Room Toilet.	 Ashwaja Mishra	Replaced New tube lights, Exhaust fans. in all suits & Conference Room as required. by Nathuram Sable/Amit bayne		all surface lights 12Wt 3 Lights 06 Wt surface - 02 No. 12Wt tube - 02 Exhaust fan - 01 28W tube light set in staircase LED light - 2 Nos.		
03		Cassette Alc leakage in Cafe Conference Room Mahanadi		 Ashwaja Mishra	Repaired by salim (Principal sign Person)	Amc Contract	Drain Pipe & Arddite	

PRINCIPAL



  
 HEAD OF THE DEPARTMENT

  
 DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	13/6/22	Jhelam Building outlet	Swapnil	Replaced New			
		Balcock break.	Kshirajun	2 inch ball cock			
2)				by Deepan (Santosh Shejval)			
2)	15/6/22	Physiology Department	DR. Mantra	Replace new 4 model		4 model	This is used board which is located in Old OPD building
		Head cabin - 2 switch	<del>Swapnil Anjan</del>	switch board in head		switch	
		are not working	<del>Shirajun</del> Mina	cabin by mene electrician <del>Shirajun</del>		boards	

DEAN



HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE


KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	08/06/2022	FMT (HOD & Professor :- HOD of 1 section each of ENT.	Swapnil Kshirsagar	Nathuram Sankale <del>atankale</del>		1 section 1 mask, 1 box	
2)		HOD of 1 section of ENT each of ENT.	Kshirsagar				

DEAN



  
 HEAD OF THE DEPARTMENT  
 DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	20/05/22	In <sup>n</sup> Pharmacology museum	<del>Kshirsagar</del>	Repaired by	—	Cement	
		tiles are opened by	suapnil	Pappu Ladiwala		15 New	
		Grilles.	Kshirsagar	with 4 Poulan		tiles.	
				2 days			
		Principal cabin toilet	<del>Kshirsagar</del>	fited granite			
		Needed corner ptes		corner piece by			
				Pappu			

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

  
DEAN

## B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	20/6/22	Venavati Building 2nd & Third floor Switching Breakers.	<u>Kishoray</u>	Replaced New Switching tiles second & third floor.	—	Tiles & granite	—
2		Zhelam Building Room No-204 in Bathroom corner Piece Needed	Kishoray	also Replaced one granite piece for corner.			

PRINCIPAL



STAMP

HEAD OF THE DEPARTMENT

DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR .NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	9/9/22	Physiotherapy B	<del>Message</del>	by Kiran Pethaw	-	Capacitor	
		college Tube lights	5/9/22	Kishor Chakraborty & Suraj Bhande	-		
		2 fans not working		Replaced New Tube & connection			
				loose capacitor			
				X M. Kulkarni			
				9/9/22			

PRINCIPAL  
*[Signature]*



*[Signature]*  
HEAD OF THE DEPARTMENT

*[Signature]*  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

  
DEAN



September 22.

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
01.	06/9/22	Tube light T.B. Lab. micro corridor, molecular lab passage Not working. <span style="border: 1px solid black; padding: 2px;">Microbiology</span>	Shingga 6/9/22	Replaced New tube lights by Sable Gombkar	22	28W tub Rod 3Nos.	
02	06/9/22	<span style="border: 1px solid black; padding: 2px;">FMT</span> - Tube light maintanace. 1) Assistant profg - 01 2) office Dept. 01 3) Tutor Room - 01 4) Library & Semina - 01 5) Associate		Shingga 6/9/22	Replace & new tube light by Sable Gombkar	22	28W 3 Nos 36W 02 Nos

PRINCIPAL



HEAD OF THE DEPARTMENT  
DEAN

B.K.L. Walawalkar Rural Medical College  
Al. Kasarwadi, Post. Sawarde  
Tal. Chiplun, Dist. Ratnagiri

**SHIRKAI ENTERPRISES**G-12,Parshuram Plaza,Parshuram Nagar,Mumbai - Goa Hwy, Chiplun, Maharashtra 415605, India,  
Maharashtra

Mobile: 8983838901 GSTIN: 27AXOPR1499K1ZJ

Invoice No.: 35

Invoice Date: 26-09-2022

Due Date: 03-10-2022

**BILL TO**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE  
Kasarwadi, Sawarde, Maharashtra  
Mobile: 8149091001

SERVICES	QTY.	RATE	TAX	AMOUNT
EPSON EB- X14 MOTHERBOARD REPAIRING + BALLAST UNIT	1.0 PCS	9200.0	1656.0 (18.0%)	10856.0
<b>SUB TOTAL</b>	<b>1</b>		<b>₹ 1656.0</b>	<b>₹ 10856</b>

**BANK DETAILS**

Name: SHIRKAI ENTERPRISES  
 IFSC Code: SVCB0006019  
 Account No: 101910101000017  
 Bank: Shamrao Vithal Co-operative Bank,CHIPLUN URBAN  
 BANK- D.B.J. COLLEGE CAMPUS

TAXABLE AMOUNT	₹ 9200
CGST @9.0%	₹ 828.0
SGST @9.0%	₹ 828.0
<b>GRAND TOTAL</b>	<b>₹ 10856</b>

Total Amount (in words)  
Ten Thousand Eight Hundred Fifty Six Rupees

**SHIRKAI ENTERPRISES**AUTHORISED SIGNATORY FOR  
SHIRKAI ENTERPRISES

Received & checked  
 Working ok (Dissection Hall)  
 projector to be fitted in

*Prabhakar*  
 4/10/22

Create professional bills using myBillBook app



Received  
*Prabhakar*  
 4/10/22

Professor & Head  
 Department of Anatomy  
 B.K.L. Walawalkar Rural Medical College  
 Sawarde Kasarwadi Pin- 415605.

765

# SHIRKAI ENTERPRISES

G-12, Parshuram Plaza, Parshuram Nagar, Mumbai - Goo Hwy, Chiplun, Maharashtra 415605, India, Maharashtra

Mobile: 8983838901 GSTIN: 27AXOPR1499K1ZJ

Invoice No: 31

Invoice Date: 23-07-2022

Due Date: 26-07-2022

### BILL TO

B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE  
Kasarwadi, Swarda, Maharashtra  
Mobile: 8149091001

### SHIP TO

B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE  
Kasarwadi, Swarda, Maharashtra  
Mobile: 8149091001

ITEMS	QTY.	RATE	TAX	AMOUNT
EXIDE CHLORIDE SAFEPOWER 12V - 7AH	6.0 PCS	746.09	1253.44	5730.0
SERVICE CHARGES	1.0	111.45	18.54	130.0
<b>SUB TOTAL</b>	<b>7</b>		<b>₹ 1314.45</b>	<b>₹ 6130</b>

### BANK DETAILS

Name: SHIRKAI ENTERPRISES  
 IFSC Code: SVCB0006019  
 Account No: 101910101000017  
 Bank: Shambhu Vithal Co-operative Bank CHIPLUN URBAN  
 BANK- D.B.J. COLLEGE CAMPUS

TAXABLE AMOUNT	₹ 4815.55
CGST @14.0%	₹ 626.72
SGST @14.0%	₹ 626.72
CGST @9.0%	₹ 111.45
SGST @9.0%	₹ 30.51
<b>GRAND TOTAL</b>	<b>₹ 6130</b>

*Received*  
 All Six Batteries Replaced  
 in Lecture theatre No 3 UPS in RMC

*Sushilraj*  
 28/7/22

Total Amount (in words)  
 Six Thousand One Hundred Thirty Rupees

SHIRKAI ENTERPRISES  
 AUTHORIZED SIGNATORY FOR  
 SHIRKAI ENTERPRISES

Create professional bills using myBillBook app



758  
 26/7/2022



# BKL WALAWALKAR HOSPITAL DIAGNOSTIC AND RESEARCH CENTRE



A/P - SHREEKSHETRA DERVAN, TAL CHIPLUN,  
DIST-RATNAGIRI, Ratnagiri, Maharashtra, INDIA

Phone: 9657510149 Email: info@walawalkarhospital.com Website: www.walawalkarhospital.com

## PURCHASE BILL

### Supplier Details

GRN No. : 758  
 Invoice No. : 31  
 Purchase Reg. No. : 0766  
 Supplier Name : SHIRKAI ENTERPRISES  
 Address : G-12 PARSHURAM PLAZA PARSHURAM NAGAR, MUMBAI- GOA HIGHWAY CHIPLUN, Chiplun  
 H.O, Ratnagiri, INDIA-415605  
 GST No. : 27AXOPR1499K1ZJ

P.O.No. : 22/WALAWALKAR  
HOSPITAL/CEM/CS452  
 P.O. : 23/07/2022  
 Date : 26/07/2022

From : BKL WALAWALKAR HOSPITAL DIAGNOSTIC AND RESEARCH CENTRE  
 Name : A/P - SHREEKSHETRA DERVAN, TAL CHIPLUN, DIST-RATNAGIRI  
 Address : 27AABTS7103H1ZK  
 GST No. : Maharashtra  
 Place Of Delivery :

Sr. No.	HSN Code	Item	Batch No.	Unit	Order Qty.	Pur. Qty.	Qty.	Rate	Disc. Per.	Amount	CGST	SGST	IGST				
											RATE%	RS.	RATE%	RS.	RATE%	RS.	
1	8507	BATTERY EXIDE 12V-7AH		Nos	6	6	6	746.06	0.00	4476.36	14.00	626.69	14.00	626.69	0.00	0.00	
											4476.36	14.00	626.69	14.00	626.69	0.00	0.00
											<b>Sub Total</b>						4476.36
											<b>Total Expenses</b>						138.98
											<b>Total Discount</b>						0.00
											<b>Total Gst Amount</b>						1314.40
											<b>Total</b>						5729.74
											<b>Grand Total</b>						6130.00

Amount In Words : Rs. SIX THOUSAND ONE HUNDRED THIRTY ONLY

Remark : FOR RMC LECTURE HALL ( Nil )

Type Name	Amount	CGST (%)	Addition / Deduction Details					Total Amt.
			CGST Amt.	SGST (%)	SGST Amt.	IGST (%)	IGST Amt.	
Others	338.98	9.00	30.51	9.00	30.51	0.00	0.00	400.00

Created By: AJIT KHAVALE

Print Time: 26/07/2022 03:23 PM

Signature  
 DEAN

B.K.L. Walawalkar Rural Medical College  
 At, Kasarwadi, Post, Sawarde  
 Tal, Chiplun, Dist, Ratnagiri





C

C

100

October

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	10/10/22	Lecture theatre No. 4 Amplifier & Mixer Not working.	Swapnil Kshirsagar	Sending for Repair For Repairs MR Mahesh Manchar			Gate Pass NO
2	13/10/2022	उपरोक्त रॉक वॉटर मॉडर ऑफ मीटर. चिपमॉड यॉर सुधारित मॉडर मीटर.		Repair by Asmit Jadhav's Nathuram Sambhu on 19/10/22 <del>Subale</del> <del>Asmit</del>		1 अंश मीटर	

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
5)		१. अंतर्गत घटक व निरीक्षण २. अंतर्गत घटक व निरीक्षण ३. अंतर्गत घटक व निरीक्षण ४. अंतर्गत घटक व निरीक्षण ५. अंतर्गत घटक व निरीक्षण ६. अंतर्गत घटक व निरीक्षण ७. अंतर्गत घटक व निरीक्षण ८. अंतर्गत घटक व निरीक्षण	}	Repair by Ashut Jadhav's Sabale on 20/10/2022 Ashut Sabale - Ashut		2 MLC अंतर्गत घटक	

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE


KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD


Boys Hostel

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1		बिचम मधील बिचम मधील बिचम tube light बिचम आहे.		Repair by Asmit Jadhav & Nathuram Subale on 19/10/2022 <u>Nathuram</u> - <u>Asmit</u>		2 nos 10W tube light & बिचम बिचम 105		
2)		बिचम :- बिचम बिचम बिचम आहे						
3)		बिचम :- बिचम बिचम बिचम आहे.						
4)		बिचम :- बिचम, बिचम बिचम बिचम बिचम आहे.		Repair by Asmit Jadhav & Nathuram Subale on 20/10/2022 <u>Nathuram</u> Asmit		10W LED Tube-01 5W LED Tube-04		

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)		विद्युत :- ROOM DOOR केस्ट केस्ट खोलने में रुकने.		Repair by Asmit Jadhav , B.K.L.		1 Pan.	
2)		ऑन मशीन tube leak. ऑन मशीन		Nathuram Sabate 20/10/2022		300 tube Road-01 100 tube list 02	

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

Medical college

Sr. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)		Pathology बिना:- मरीज Tube light दिश आहे.		Repair by Nathuram Sabale & Asmit Jadhav on 22/10/2022  Asmit 22-10-2022		10w Tube		
2)		बिना खोलाविल बिना:- मरीज Tube light दिश आहे.					light:- 3 nos	
3)		बिना उपेक्षागत बिना:- खोलाविल Tube light दिश आहे.						
4)		Amf बिना बिना:- Tube light दिश आहे.						
5)		Amf Examinall बिना Tube दिश आहे.						

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

*[Signature]* 24/12/22  
DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

Medical college

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)		Anatomy:- Tutor room:- Fan broken since	}	Repair by Amit Sathav & Nathuram Subale on 20/10/2022		1 Fan replaced.		
2)		Professor room 360 tube is not					50 tube changed	
3)		Gents toilet:- water not is not.			<del>Subale</del> Amit 22-10-22		100 tube changed	
4)		Passage water tube is not.						
5)		Anatomy first demo room water tube is not						

PRINCIPAL




HEAD OF THE DEPARTMENT

 24/12/22

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

*Medical college*

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)		Pharmacology सिम्ट - मेलिफ ट्यूब लिफ्ट ऑफ मीटे.		Repair by Nathuram Sabale & Asmit Sadhal on 22/10/2022 <del>Nathuram Sabale</del> Asmit 22-10-2022		100 Tube		
		सिगनेचर सिम्ट ट्यूब लिफ्ट ऑफ मीटे.					लिफ्ट - 03081	
2)		मिक्रोबियोलॉजी सिम्ट ट्यूब लिफ्ट ऑफ मीटे.					3 सिम्ट ट्यूब	
		मिक्रोबियोलॉजी सिम्ट ट्यूब लिफ्ट ऑफ मीटे.				145		
3)		Microbiology सिम्ट ट्यूब लिफ्ट ऑफ मीटे.						

PRINCIPAL

*[Handwritten Signature]*



HEAD OF THE DEPARTMENT

*[Handwritten Signature]*  
24/10/22  
DEAN



# B.K.L.WALA WALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
6.	23/10/22	NAAC office	<i>Asmit</i>	All tube lights & fan checked by Asmit all working OK <i>Asmit</i> 23-10-22.	-	-	-
7.	23/10/22	Physiology - All clinical Physiology Lab fan is NOT working. Need to be checked all fans & tube light / switches	<i>Asmit</i>	Fan Regulator connection was loose Repaired by Asmit & ALSO checked all fans switches & tube light by Asmit all working OK <del>Asmit</del> 23-10-22	-	-	-
8.	23/10/22	MEU (medical Education unit) 4 tube lights Not working	<i>Asmit</i>	Replared New tube Rods by Asmit Jadhav	09	28 w tube Rod.	

PRINCIPAL



*Asmit*  
23-10-22

HEAD OF THE DEPARTMENT

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
9.	23/10/22	MEU - tube lights & 2 fan Not working - when fan was switched on there were tripped in NTCB Panel.	Shirgaur 23/10/22	Old tube Paperi modified and Replaced 2 NAS 1 Fan Regulator Replace & Loose connection of fan Repaired all by Asmit Jadhav & Jitendra Gujar	-	36W Rod 1 Regulator (old)	-
					Asmit 23-10-22		
10.	23/10/22	Vidish Building - 1 Parking tube lights Not working. First floor tube light Not working, third floor tube light Not working	Shirgaur 23/10/22	Replaced tube and floor New tube lights on Respective floors by Asmit & Dhurak	89	5W tube LED tube lights 1- Parking 1- First floor 1- third floor.	
					Asmit 23-10-22		

PRINCIPAL




HEAD OF THE DEPARTMENT

Asmit  
24/10/22  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

*Library*

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)		for discription of new tube oil etc.		Repair by Jitender Gogoi Amar Dhumak on 22/10/2022		10w tube lead oil etc.	
2)		for discription of college		<del>Repair by</del>			
3)		Lecture hall 02 & Reading Hall-01 Fan fitting (number 10 & 11 Romc)		Repair by Jitender Gogoi Amar Dhumak on 22/10/2022		efan fitting.	

PRINCIPAL




HEAD OF THE DEPARTMENT

*24/12/22*  


DEAN

**B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE**  
 KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

Sr. NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	23/10/22	52 ft. corridor tube light not working	<u>Ashisagar</u>	Repaired by Asmit Jadhav Asmit Jadhav Repaired by <u>Asmit</u> 23-10-22	09	28 W Rod.	-
2	"	Principal cabin corridor tube not working	<u>Ashisagar</u>	Asmit Jadhav & Dhurak Asmit Jadhav Repaired & supply checked ok 23-10-22	Asmit 23-10-22	36 W old tube Patti modified	-
3	"	Central Research Lab tubes not working	<u>Ashisagar</u>	Asmit Jadhav Repaired & supply checked ok 23-10-22	Asmit 23-10-22	-	-
4	"	Lecture theatre No 1. one tube not working	<u>Ashisagar</u>	All tubes of fan checked by Asmit Jadhav checked ok Asmit 23-10-22	-	-	-
5	"	Co Central Block 2 LED Not working	<u>Ashisagar</u>	Replaced New switch by Asmit working OK (2x2) LED Asmit 23-10-22	Asmit 23-10-22	Switch one 1	-

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

DEAN

*[Signature]*

B.K.L. Walawalkar Rural Medical College  
 Kasarwadi, Post Sawarde  
 Tal. Chiplun, Dist. Ratnagiri

24/11

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
11.	23/10/22	Girls Common Rooms - tube light NOT working	<u>P. Shirsagar</u>	Re Holder was broke. so Replaced New Holder & checked ok by Asmit & Dhumak.	-	1 Holder of old Patti	9
12.	23/10/22	Server Room - tube light NOT working	<u>P. Shirsagar</u>	Replaced New tube Rod by Asmit & Dhumak.	9	28 w tube Rod.	
13.	23/11/22	Animal House - 28 w tube lights NOT working 3 Nos.	<u>P. Shirsagar</u>	Replaced New 36 w old modified tube lights 3 Nos. by Asmit Jadhav		Old modified 36 w tube lights.	

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
14. <del>23/10/22</del>	23/10/22	Pantry - one tube light Not working	<i>Shriwast</i>	Replaced New tube light by Asmit Sadhan	9	28 W tube Rod New		
23/10/22	*	<p>पंजी, जिनंद्र गुजर, अमर धुमड हे तिथे जगंजिजूनने OPD ला वापरलेले 11 नं. स्टोअर मध्ये असलेले मटेरिअल चेक करीत होते व त्यामून जुन्या 36 W tube light, 28 W tube lights अर्दीजे 20 वग कुकस्त केला व Electric Board तपासून त्यानीच चांगले बोर्ड, Plates व बरेणे कुकस्त ककडा बनिते बोर्ड तयार केले करवावळी बांधणी करून ठेवले आहेत.</p>						
				Plates - 6M - Switches - Regulators - Adapters -		tube Patti 36W - Rod tube 36W - tube Rod 28 W - 2 Nos		

PRINCIPAL




*J. Lenasa Greiser*  
[Signature]

HEAD OF THE DEPARTMENT

DEAN



B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post, Sawarde  
Tal. Chiplun, Dist. Ratnagiri

## B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
01.	25/10/22	<del>Girls</del> Girls Reading Hall - 2 tube lights Not working, 1 Fan Not working	P. Shrivastava 25/10/22	Repaired by Asmit & Gujar working ok. Fan Regulator Connection loose - Repaired.	-	28 W choke	01
02.	25/10/22	Issue counter. tube light Not working. 28 W.		P. Shrivastava 25/10/22	Replaced old modified 31 W tube light & Rod by Asmit & Gujan.	-	Old Modified 36 W tube to Patti & 31 W tube Rod. 02 W
03.	25/10/22	Computer E-Learn'g Hall - tube light Not working. (28 W)	P. Shrivastava 25/10/22	Replaced old modified 36 W tube light & Rod by Asmit & Gujan.	-	Old Modified 36 W tube Patti & 36 W tub Rod.	01 Nos

PRINCIPAL



P. Shrivastava  
25-10-22

HEAD OF THE DEPARTMENT

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
04.	25/10/22.	<p><del>श्री जयजन साहेबांच्या परवानगीने</del>  <del>केसी इमारती मधील साईट ऑफिस मधून जुने</del>  <del>OPD चे Electrical मॅट्रोएक डिव्हासोअर बोर्ड, पध्दा फॅन रोड</del>  <del>घेऊन आले. त्यानेच आकस्मिक असलेले सामान 152 नं आ हॉल</del>  <del>मध्ये नष्टवा काढून ठेवले. सदर काम आकस्मिक जाधन व जितेंद्र गुडा</del>  <del>ह्या दोन Electrical वने केले व त्यांच्या मॅट्रोएक 2 मॉड्युल व शुभम</del>  <del>चव्हाण व अक्षय चोखे टि कॉलेज मधील मुले दिसी लेती</del></p>	<p><del>Shiragav</del>  <del>25/10/22</del></p>	<p><del>X</del></p>			
05.	25/10/22.	<p>ऑफिस मधील बोर्डची                      काय तुटली आहे.</p>	<p>Shiragav</p>	<p>Replaced New                      18 Module Board                      Vinay. by                      Asmit &amp; Guyan</p>	-	<p>Old 18 Modular                      Vinay switch Board                      From Kashi office</p>	


PRINCIPAL




Asmit  
 25-10-22

HEAD OF THE DEPARTMENT

DEAN





B.K.L. Walawalkar Rural Medical College  
 Kasarwadi, Post Sawarde  
 Tal. Chiplun, Dist. Ratnagiri



# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
02	26/10/22	Central Block - Common Toilets Gents & Ladies (Anatomy side) switches Broken.	 P. Shindagar 26/10/22	Replaced 12 Mod. Board & 8 switches		Replaced Old 12 Modular switch socket Board, 3 Modular switch socket Board in Gents toilets & 7 Modular switch socket Board in Ladies toilet	
				3 Mod. Board & switches in 8 Gents Toilet			
				Replaced 7 Mod. Board & switches socket in Ladies Toilet by			
				Asmit & Gyan			Kasi site office old material Board
				Asmit 26-10-22			
03	26/10/22	Central Block - common Toilets Gents & Ladies (Physiology side) switches Broken.	 P. Shindagar 26/10/22	Replaced 6 & 8 Modular switch Board in Gents & By Asmit & Gyan		Replaced Old 6 & 8 Modular switch Boards from Kasi site offices	
				Asmit & Gyan 26-10-22			

PRINCIPAL




HEAD OF THE DEPARTMENT

  
 DEAN  
 24/11/22

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
01.	26/10/22	Store case No-6 (Anatomy) switches Broken	[Signature] 26/10/22	Replaced		Old 2 Modular	
		Store case No-1 (Biochemistry) switches Broken.		Switch Board		Board from	
		Store case No-2 (Physiology) switches Broken		in Store case		Kasi & Site	
		Store case No-3 (Central Block switches Broken)		No. 1 to 6 on		office.	
		Store case No-4 (Central Block switches Broken)		Ground Floor			
		Store case No-5 (Anatomy) Dissection key switches Broken.		Asmit & Sable			
			X	Asmit 26-10-22			

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
 Al. Kasarwadi, Post. Sawarde  
 Tal. Chiplun, Dist. Ratnagiri

[Signature]  
 24/10/22

# B.K.L.WALA WALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
04.	26/10/22	Anatomy Reserch Lab Board supply loose connection thats why tube light is not working.	Shirbaga 26/10/22	Checked by Asmit & Gyan Repaired Board supply O.K. & tube is working condition.			
05.	26/10/22	Anatomy Demo Room No.1 - 2 tube lights are Not in working.	Shirbaga 26/10/22	Replaced 02 36 W & 28 W tube light & Rod Patti by Asmit & Gyan		Old 36 W tube patti 01, 36 W Rod-01 28 W Patti 0-01 28 W Rod 0-01	
							all above are modified.
06.	26/10/22	Anatomy Musium - tube lights & Fans are Not working. 6 fans & 7 tubes	Shirbaga 26/10/22	Checked by Asmit & Gyan Need to change switches			

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

B.K.L. Walawalkar Rural Medical College  
Al. Kasarwadi, Post. Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALA WALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
<del>01</del> 01.	27/10/22	Acadmic office & Registrar office Boards swithes are Broken.	Pashirga 27/10/22	Replaced Modified board in Acadmic Student section and Registrar cabin	-	Old Modified 12 Modular switch socket Board in student section	
				by Gujan & Rohan		6 Modular Plate & switches in Registrar cabin	
						above material in room Kasi office	
02	27/10/22	Tube is Not working in Registrar cabin	Pashirga 27/10/22	Replace Repair by Gujan & Rohan		New 36W tube Chacke 2 Nos. & 36W tube Rod old modified material	
03.	27/10/22	Infront of photography units - swithen Board is Broken	Pashirga	Replaced New by Jitendra Gujan & Rohan		Replare old modified 12 Modular switch plate & 16 Amp switch socket board From Kasi office material	

PRINCIPAL




27/10/22

27/10/22

HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
04.	27/10/22	Gen's toilets tube light Not working 2. No 2	Shivaga	Replaced tube lights by Jitendra Gajjar	09.	36W tube set multiple old & 5W led New.	
03.	27/11/22	Biochemistry storeroom No. 1 2 tube lights are Not working		Shivaga		Repaired by Jitendra Gajjar	

PRINCIPAL





HEAD OF THE DEPARTMENT

24/11/22





DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

Boy's Hostel Grant.

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
2)	24/11/2022	Room No 214 Tube light not working (360 Tube)	 24/11	work done by Nathuram Sabale on 25/11/2022		20W LED Tube light	
3)	---	Room No 203, 204, 207, 201, 201 heat transformer is of 0.5 HP			<del>work done by Nathuram Sabale on 25/11/2022</del>		Transformer
1)	24/11/2022	Room 204 socket not working	 24/11/22	work done by Nathuram Sabale		socket	

PRINCIPAL




HEAD OF THE DEPARTMENT

  
24/11/22

DEAN



B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALA WALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

Boys Hostel Department


FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	25/11/2022	Room No:- 116, 115, 103, 104, 106, 107, Host toilet Host Tube light	 Prashant 25/11/22	Work Done by Nathuram Sabale on 25/11/22		5W LED Tube light 14 Nos		
2)	104, 112, Host						4W LED 02 Nos.	
3)	102 & 110 Host						4W LED - 02 Nos.	
		Host generator.						
1)	25/11/2022	202, 203, 204, 214, 207, 211, 210, 205, 205 Host toilet Host Tube light	 Prashant	Work Done by Nathuram Sabale on 25/11/2022				

PRINCIPAL




HEAD OF THE DEPARTMENT

  
22/11/22

DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	27/11/2022	Anatomy Museum :- New Board fitting. मर्यादित कोठे साकार व्हावे आहे साकार कोठे साकार कोठे साकार कोठे साकार	<i>[Signature]</i> 27/11/22	Replace 3 new fitting Board total 4 nos 18 modules by Nathuram Sabale on 27/11/2022 - Sabale.		18 modules - 04 nos 40 Nos switch 12 Nos regulator 04 nos socket	

PRINCIPAL *[Signature]*



*[Signature]*  
HEAD OF THE DEPARTMENT  
27/11/22  
DEAN



# B.K.L.WALA WALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	18/11/2022	Anatomy :- Dissection hall cold storage :- New board fitting (कोई साक्षात् सातों 2012 कागजों में कागजों)	Swapnil Kishore	New board & switches by Nathuram Subale on 18/11/2022 at Subale.		07 Nos switch 6 Amp 02 Nos Regulator 12 module - 01 2 Reg. cable.	
2)		Dissection hall :- Embalming Room :- New board fitting (कोई साक्षात् सातों 2012 कागजों में कागजों)	Kishore				04 Nos switch 6 Amp 01 Nos Regulator 07 Nos module & 1 Reg. cable.

PRINCIPAL



HEAD OF THE DEPARTMENT


24/12/22

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	20/11/2022	Boy's Hostel (गोठानि कक्षा)	 20/11/22	Replace 8 New		01 Nos 36W		
		Room NO:- 110 - Tube Not working.		Fitting Tube light.			Tube Road.	
		-11- 113:- Tube not working.		Switch by			06 Nos 20W LED	
		-11- 105:- Tube not working & Holder, Board girded wire		Nathuram Sabale.			Tube light.	
		-11- 103:- Tube light not working		<del>Nathuram Sabale.</del>			04 Nos Switch	
		-11- 201:- Tube light not working		<del>Nathuram Sabale.</del>			6 Nos 40W LED	
		-11- 202:- Tube light not working.			01/12/2022			
		-11- 203:- Tube light not working & Switch not working.						
		-11- 204:- Switch not working						

PRINCIPAL





HEAD OF THE DEPARTMENT

24/12/22



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

Sr. NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL

STAMP

HEAD OF THE DEPARTMENT

DEAN

B.K.L.Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	16/11/2022	Library - common toilet	<i>[Signature]</i>	work Done by		1 Jet spray	
		Leadies : Jet spray	<i>[Signature]</i>	Abhishankar Sabunde		with pipe	
		not working		on 16/11/2022			
				<del>Abhishankar</del>			

PRINCIPAL

*[Signature]*



*[Signature]*

HEAD OF THE DEPARTMENT

24/11/22

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALA WALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL. CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRIPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	27/10/22	Autoclave coil replaced (no. 2)	Rohit Chavan Surya Chavan	New wire & core			
2	28/10/22	Biosafety cabinet heater connected but not working	S. Jondra Gujar	Replace d'fow Autoclave <u>Chhisaq</u>			

PRINCIPAL




HEAD OF THE DEPARTMENT



24/12/2022 (DEAN)

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	02/12/2022	Anatomy museum मॉडेल तयार करणे वॉर्ड असावत. उच्चतर सुधार सुधारणे सादर.	<i>[Signature]</i> 21/12/22	work done by Nanthuram subale on 02/12/2022		मॉडेल:- 38 नॉट.	
		Lecture hall 2 मॉडेल उच्चतर सुधार सुधारणे सादर. 02/12/2022 ते 11 नॉट वॉर्ड असावत.	<i>[Signature]</i> 21/12/22				पेपर:- 4 नॉट. मॉडेल:- 11 नॉट. 16 moulder:- 11 नॉट.
2)							

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

*[Signature]*  
21/12/22  
DEAN

**B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE**  
KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO

PRINCIPAL 



HEAD OF THE DEPARTMENT   
DEAN  
B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	10/01/21	Pathology Dept:- Grossing section prior wash of FB	<i>[Signature]</i> 10/1/21	Replace	1792	Flexibile pipe	
2)	11/01/21	Pathology Dept:- 3 switch buttons 1 awnubert, 3 pound LEP circuit	<i>[Signature]</i>	Replace switch - <i>[Signature]</i> 12/01/21	1792	3 switch 3 awnubert, 3 pound LEP	
3)	11/01/2021	FMT:- HOD & Professor - 1 switch	<i>[Signature]</i>	Replace switch - <i>[Signature]</i> 12/01/21	1789	1 switch	
4)	24/01/2021	Molecular Lab (microbiology)	<i>[Signature]</i> 24/1/21		-	screw driver	
		Door closer not working properly					
5)	31/01/21	Anatomy:- Dissection Hall - 13 switch	<i>[Signature]</i>			13 switch	
		Office Anatomy 3 switch.	<i>[Signature]</i> 31/1/21		1813	3 switch	
		Anatomy museum 1 switch				1 switch	
		Central Block Corridor - 2 switch	<i>[Signature]</i>			2 switch.	
		Molecular Lab Passage 2 switch			1820	2 switch.	

PRINCIPAL



*[Signature]*

HEAD OF THE DEPARTMENT  
DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	05/03/21	FMT Dept:- Demo 3 museum 5 nos switch 10 nos	<i>[Signature]</i> 05/03/21	replace 10 nos switch <i>[Signature]</i> 06/03/21	192164	10 switch	
2)	16/03/21	Pathology:- Histopath Grossing section outlet pipe broken & Am room Bussing pipe	<i>[Signature]</i> 16/03/2021	replace also pipe purchase new 3 nos pipe form pokhar hardware		5 nos Bussing pipe	
3)	16/4/21	Pathology:- Histopath 3 Round LED Light	<i>[Signature]</i>	replace 3 nos round LED light. <i>[Signature]</i> 17/4/21	164	3 Round LED Light	
4)	28/4/21	Community medicine Passage Board switch.	<i>[Signature]</i>	replace 2 switch <i>[Signature]</i> 28/4/21	58	2 switch.	
5)	28/4/21	Lecture hall 3:- 7 nos switch	<i>[Signature]</i> <i>[Signature]</i>	replace 7 switch <i>[Signature]</i> 28/4/21		7 switch.	
6)	17/05/21	Biochemistry Dept:- 1 no revolving chair hydraulic cylinder Tammed	<i>[Signature]</i>	replace new cylinder <i>[Signature]</i> 24/05/21		1 cylinder	

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	27/05/21	Community medicine :- Professor Room Fan not working	<i>[Signature]</i>	Replace new fan 28/5/21	58	1 fan	
2)	03/06/21	Pathology - histopath lab a/c switch	<i>[Signature]</i>	Replace switch 04/06/21	317	3 switch	
3)	19/06/21	Anatomy :- 4 tube not working	<i>[Signature]</i>	Replace new tube set 21/06/21		4 tube set 36 W.	
4)	01/7/21	Psm Dept. office fan switch not working.	<i>[Signature]</i>	Replace switch.		1 switch	
5)	02/07/21	Anatomy Dept - Tutor room Fan switch not working.	<i>[Signature]</i>	Replace switch. 03/7/21		1 switch	
6)	1/09/21	Community medicine Tube light & switch button broken.	<i>[Signature]</i>	Replace tube & switch 11/09/21		36 W tube & 2 switch.	

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	10/01/21	Boys hostel - Room no 20 vent ( Day Balcony vent closed)	<i>[Signature]</i>	13/1/21 <i>[Signature]</i>	-	-	
2)	14/1/21	Boys hostel student - 111338 5 LED light - 5V 84 put fitting 16 tube and 20 nos of 24g Eusef used.	<i>[Signature]</i>	Replace <del>tube</del> 13/1/21		5V LED light - 20 put putti 16 tube and 20 nos of 24g Eusef used.	
3)	17/01/21	Boys hostel student 101121 20 20 nos X 2 - 2 nos steel sheet. 2 nos sheet - 39 2 nos. 2 nos sheet - 47 2 nos. 2 nos sheet - 6 2 nos.		Boys hostel 2 nos 13/1/21 <i>[Signature]</i> 13/1/21			
4)	14/1/21	2 nos (Boys hostel) <del>vent</del> vent 2 nos	<i>[Signature]</i>	New fitting passage <del>tube</del> 13/1/21		5V LED - 05 nos 24g Eusef 56 nos	

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	14/01/21	स्त्रोअर (2045 model) उतर मरत मरत मरत मरत मरत.	<i>P. N. N.</i> 16/1/2021	अनू फीरिंग अरत. <i>P. N. N.</i> 16/1/21		9W LED 150W 24' मरत 56' अरत.	
		स्त्रोअर अरत अरत अरत.	<i>P. N. N.</i>			12W - 0.50W 9W - 0.31W LED अरत.	
2)	14/1/21	नेरत मरत + अरत मरत मरत.	<i>P. N. N.</i>	अनू फीरिंग <i>P. N. N.</i> 16/1/21		9W LED - 160W 12W LED - 02 6' अरत. 12' अरत.	
3)	19/01/2021	नेरत मरत अरत अरत अरत	<i>P. N. N.</i> 19/1/2021	अरत अरत.		T. 28W3, अरत 02 36W 3 CFL-2	
		Room no 95, 98, 99, 101, 102, 105, 168 107, 111, 118, 119 मरत.	<i>P. N. N.</i>				
4)	29/1/21	अरत 10 अरत अरत	<i>P. N. N.</i>	अरत		10 अरत 36W. अरत अरत.	
5)	13/2/21	स्त्रोअर 304 अरत अरत अरत अरत.	<i>P. N. N.</i> 13/2/2021	अरत <i>P. N. N.</i> 14/2/21		1 अरत, 1 अरत.	

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	15/01/2021	Library (Unit tube used)	<i>[Signature]</i>	change to tube 15/1/21		1 unit tube 1 unit		
2)	20/1/21	Center Library :- 012151111 - Microbial tube 01 tube.	<i>[Signature]</i> 23/1/2021			3 tubes		
		2115 - Microbial tube 01 tube. 01 tube - 01 tube.					31 tube 215 7 36 W tube	
		2115 Microbial tube - Microbial tube 3 tube.			Replace exchange		36 W tube	
		Microbial 3 Microbial tube 01, 01, 01			For library 23/01/21		4 Microbial	
		Microbial tube :- 2 tube 3 Microbial tube - 2 tube.			<i>[Signature]</i>		12 tube	
		2115 Microbial tube Microbial tube 2 tube						
		Microbial tube :- Microbial tube - 7 tube Unit 4, tube - 14						
		Library :- Unit 1						
		State of / Microbial tube :- 02 Microbial tube, State of tube :- 01 tube 01		<i>[Signature]</i>				
		Unit 13, Microbial tube 4						

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

*[Signature]*

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	01/05/21	Library Stock record update 2021/21	<i>[Signature]</i>	Replace <del>stock</del> 21/05/21	1903	5 sets of <del>spare</del> 21/05/21	
2)	01/05/21	HOD Library Dept:- Revolving chair repairing	<i>[Signature]</i> 17/5/21	Replace cylinder <del>stock</del> 24/05/21		1 cylinder	
3)	25/10/21	Center Library :- common Taitu alator set spray	<i>[Signature]</i> 21/11/21	Replace <del>stock</del> 24/11/21		35 sets spray	

PRINCIPAL

*[Signature]*

STAMP



*[Signature]*

HEAD OF THE DEPARTMENT  
DEAN

**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE**  
**KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606**  
**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	28/10/2021	36ml tube अचल आहे.	<i>[Signature]</i> 28/10/21	Replace 36ml tube 29/10/21		36ml tube Sant.	
2)	10/02/21	lab light not working.	<i>[Signature]</i> 10/2/21	Replace 10/2/21		SAMP - 2 2465 215	

PRINCIPAL

*[Signature]*

STAMP



*[Signature]*

HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
15	26/1/21	Girls Hostel:- (A/Canti, Chanchala & Venna building, Tubelight not working - room no:- 86, 110, 4, 3, 103, 162, 90, 55, 31, 27, 36, 23, Passage tube light, * Fan not working & holder broken.	26/1/21 [Signature]	Repaired by Dodekar 30/1/21	1885		

PRINCIPAL

[Signature]

STAMP



HEAD OF THE DEPARTMENT

DEAN

[Signature]



B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri



# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	30/1/21	विद्युत विनिर्देशक उपकरणे १ मरुतलेले भाग.		Replace 10 tube		10 नुसार भाग 28 वी.	
2)	15/2/21	विद्युत (Drum) मरुतलेले भाग 2 Fan नुसार काम करत नाही.		Replace 2 tube		1 मरुतलेले 1 मरुतलेले भाग.	

PRINCIPAL



STAMP

HEAD OF THE DEPARTMENT  
DEAN

**B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE**  
 KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606  
 FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	10/12/2021	Assistant Professor - 1 Tubelight					
2)	10/10/2021	Associate Professor - 1 switch	Shubh		1718		
3)	10/10/2021	Musum - 2 pair set Tubelight		Shubh		1 snider switch	
x 4)	10/12/2021	Dermo Room - 1 Fan		all done done by electrician		28 w tube set tube	
5)	10/10/2021	Bacteriologi lab - 1 Fan				2 fan cap capacitor	
x 6)	10/10/2021	Tuberculosis lab - 1 Fan		1) H. desh Dodekan,		1 capacitor	
7)	10/12/2021	Immunology lab - 1 Tubelight		2) Sachin Sawant		1 tube Rod	
8)	10/12/2021	Serology lab - 1 Tubelight		3) Nilesh mene		3 tube light Rod & capacitor	
		- Side Tile damage		on 14/15/16 dec 2021		28w tube Rod	
9)	10/12/2021	Media Preparation storage Room - 1 Tube (36w)				1 capacitor	
10)	10/12/2021	Office cum clerical Room 25w 1 Tubelight 2 switch				1 tube	
						36w tube Rod	
						28 w tube	
						1 switch	

PRINCIPAL

STAMP




HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
x 11)	10/12/2021	Practical Lab-2pair 1 set tube 28w light, 1-Fan		all done done by 1) Hitesh dodekar 2) Sachin sawant 3) Nilesh mune. ✓		28 tube 1 capacitor		
x 12)	10/12/2021	Dept of Microbiology Passage 28w tube & panel Tube light Holder hanging						
13)	10/12/2021	Lab Passage - 1 Tubelight 28w					36 watt	
14)	10/12/2021	Staff Room Passage-1 Tube 28w light					tube	
15)	10/12/2021	Store Room. 1 Tubelight Red 28w.					28w tube	
				Adas				

PRINCIPAL

STAMP



HEAD OF THE DEPARTMENT



DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	07/07/20	Rural medical - कर्मचारी व Pharmacy कर्मचारी						
		* Anatomy HOD	 7/7/20 To Mahajan Sir					
		* Pathology museum & lab		महजान साहेबसाहेब हे				
		* Hall No - 152		काम करणे द्यावे				
		* Microbiology lab & museum						
		अन्वय - पाठक शाळा द्यावे ते काम करणे द्यावे						
2)	19/07/20	boys hostel 5 Fans Not working.	 19/7/20	Repair by mene & Himesh on (21/07/20)		E. Regularly		

PRINCIPAL







HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	09/08/20	College council Hall मी Hand mic व ऑडिओ एल NO 1 अ		Repd by yatin kalanni (pune)	-	-	-
		College mic 2210 अंतिम 300 अंतिम व मीटर pay component (पुन) अंतिम वापरणाले अंतिम	<i>[Signature]</i> 9/8/20				
2)	21/08/20	जाईल लॉरेल corridor मी 12 lot मी L.E.D लॉरेल डिवाइस वापरणाले				12w Round LED-3Mg	
		① डीमिंग - 8 + 12 = 20M		<i>[Signature]</i>		AS in	
		② डीमिंग - 10 Nos		मीटर व मीटर वापरणाले		<u>Discription,</u>	
		③ डीमिंग - 18 Nos					
		④ College curcl. - 04					
		⑤ case buiding. - 13 Nos					
		Total - 62 Nos					

PRINCIPAL

*[Signature]*



*[Signature]*

HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD


SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	01/09/20	Olympic case मा खोला		खोला 4/14/20			
		पावसाळ्याचे आवा माता 3,10/1	Rishab 11/9/21	दे माता 4/14/20			
		मा खोला 4/14/20					
	10/9/20	Rmc Health lecture theater. No.4	Rishab 11/9/21	श्री. महेश महेश			
		strong focus of Area all class		Inform to management			
		दुरुस्त प्रकारात ही कार्ये					
	15/9/20	Rmc Health common toilet	Rishab	सिलेरा खोला			
		Health center मध्ये सुध्दा कार्य सुधारित	Rishab				
		मा खोला 4/14/20		सिलेरा खोला			
		मा खोला 4/14/20					

मा खोला 4/14/20

PRINCIPAL




HEAD OF THE DEPARTMENT






DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	16/9/20	मिडीसल स्टोअरमि स्प्रींकलस रोकल एवमि सिलेक्ट मे ग्राउंड मीन सुवा द 3046C वरु उरुमल सिलेक्ट मे एलान्गु सुवा.		मि ड्रेअ Repaired by Kiran Patil Sprinke by Santosh shajmal.		B Faw Eight 5 MCB	
2	20/9/20	Library प्लास्डल मल्लम कंपीटर Rover all plumbhichiam आवुल्ल मल एवमि सिलेक्ट मे 36137 मल्ल		मल्ल मल्ल Repaired by Shubhu manoj Dean			
3	24/9/20	microbiology department of lecture Hall No. 4 A/c maintenance मल्ल प्लुसुमल मल्लुगु वी.		मल्ल. फेअर Alurindan		B Hinge	

PRINCIPAL




HEAD OF THE DEPARTMENT




DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	10/10/20	मिनी २२० वॉल्ट अंतराल मेलीत १२ २२० वॉल्ट अंतराल मिनीकॉल्ट		मिनी २२० वॉल्ट	-	२४ White	३३५
		६ both २ tables for each				-	Right
2)	14/10/20	मिनी २२० वॉल्ट अंतराल मेलीत Principal cabin d kitchen office मेलीत Parallel phone connection मेलीत न मेलीत मेलीत मेलीत		मिनी २२० वॉल्ट Pacee	-	3 meter telephone wire	
37	18/10/20	मिनी २२० वॉल्ट अंतराल मेलीत मेलीत न मेलीत मेलीत मेलीत		मिनी २२० वॉल्ट Kant Aluminum	-	-	-

PRINCIPAL



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	22/10/20	Micro biology Dept. Health TB. Lab wall A/C staff room and first floor water tap.		airtl.			
		Leakage full No. 4 staff room water tap and first floor water tap.		Repaired by Kantia	-	-	-
		Leakage full No. 4 staff room water tap and first floor water tap.	22/10	only window openable and remove			
	26/10/20	Boys Hostel Health check up and water tap and first floor water tap.		airtl.			
	29/10/20	A/C - college council computer fan and water tap.		IT. fixing and maintenance			

PRINCIPAL




HEAD OF THE DEPARTMENT






DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	12/11/20	plnc - lecture hall no.1 HDMI cable 5mtr सिस्टम		सोप्या उद्दे		HDMI Cable 5 mtr	
		lecture hall no.2 classroom demo HDMI projector classroom desktop monitor		सोप्या उद्दे			
	17/11/20	विद्यार्थी विज्ञान शाळा Histopath. phthoroom Reporting Room शाळा विद्यार्थी शाळा शाळा शाळा		सोप्या उद्दे		जोडणे शाळा	

PRINCIPAL










HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	21/11/20	मात्र BOYS एरिक्टर री मिमांसी रीम ग्रेडिंग करी से फोल्ड मीटर मी.ए.		ग्लिड सोख			
	25/11/20	वेरुमी - 35 मी - 25 मी ग्रेडिंग मि माइक्रोमिटर क्री - 01 मी माइक्रोमिटर क्री - 01 मी मिमांसी ग्रेडिंग - माइक्रोमिटर क्री 01.		मिमांसी क्री		Tube - 25 मी Exos - 02 मी	
	27/11/20	molecular lab microbiology door case not working properly		मिमांसी क्री			

PRINCIPAL







HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	9/12/20	PSM Dept. office Dr. Pahal chopade fan switch Broken		By chicvatal	8217	capul switch	
19	15/12/20	Anatomy Dept. tube light unit not working 4 tube light replace		Akshay chogle	3917	28 w tube Right	
27	23/12/20	संस्कृत परिसर २० रातोंची २२ रातोंची स्टोअर घटती हो Boys रिकॉम २ मिनट २० मिनट स्टोअर मेल ३० मिनट स्टोअर मेल ३० मिनट स्टोअर मेल		30 मिनट मिनट			

PRINCIPAL





  
HEAD OF THE DEPARTMENT  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	25/12/20	Biochemistry Dept. HOD		N. Subale		Hypodermic	
		Recalibrating chair electrolyte	<u>Sharma</u>			cylinder.	
		cylinder jammed					
	28/12/20	community medicine dept.		Dr. Prave		capacitor	
		fan is not working in	<u>Sharma</u>				
		professor room					
	30/12/20	Anatomy Department		Dr. Parash		Refrigerator	
		Dr. Parash fan	<u>Sharma</u>	<u>Parash</u>		switch	
		switch broken					

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	10/01/2019	Pathology Dept Corridor section अखंड विली		Replace by cable			
		7087.		on 12/01/2019		3 switch 6 LED tube	
		8 Pathology Dept 3 switch button 6 Tube 3 LED tube					
	15/01/2019	Anatomy Lab - 5 switch		Replace by		3 switch	
		4 Dissection Hall - 13 switch		hidden & men		13	
		1 Museum - 04 switch		electrical		04	
	19/01/2019	ऑपरेशन थिएटर वॉल - 1 Tube					
		* Student teaching room - 2 fan		Replace by		1 Tube 2 - regulator 2 - chole	
		* Health room - 2 fan fresh					
		work in					

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	24/01/2019	Canteen Library :- Electric tube of 500 watt down	Shivraj	replace & change by Alilash mane.		28V. T. 6 watt switch - 2 nos Fan capacitor - 4	
		03 switch 52 fan not working.					
		Student reading hallc. Electric					
		tube 2 fan 4 not working.					
2)	26/01/2019	विद्युत त्रुटि का कारण	Shivraj	Replace & change by Alilash mane		28W. Tube 6W 2 capacitor.	
		दोनों मालूम Room 6, 8, 9					
		मालूम 2 फैन रूम 6 249 सूचना					
		* अर्थ :- Room - 213 मालूम					
		मालूम मालूम विद्युत त्रुटि		विद्युत त्रुटि.		मालूम.	

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

*[Signature]*

*[Signature]*  
DEAN

**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE**  
**KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606**  
**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	10/02/19	Physiology main dar firing	<i>[Signature]</i>				
		Clinical lab dar stenospro					
		Heart lab book new plot			दिनेश मेडिकल		
		Asst prof dar Jam → stenos			काश जेवली डॉक्टर		
		Not working			मिडिल		
		HOP main dar stenos not work					
	15/02/19	Anatomy histolab steel	<i>[Signature]</i>				
		wedding board			कारवेल कट्टी		
		bio Chem lab steel bench			कम पुर्ण कर		
		Physiology Demo Room bench					

PRINCIPAL

*[Signature]*



*[Signature]*

HEAD OF THE DEPARTMENT




DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	11/02/2019	center research lab Aluminium partition against sound sheet.		airnt airnt airnt net.			
		* common toilet:- drainage with inflow net.		2nd floor airnt			
		T.B. Lab :- Distilled water plant nit coil access sheet net.		replace by nitest maner		2 coil	
2)	23/02/2019	Pathology :- histo & cytopatho. Histo 3 tube rack not working.		Replace by nitest Dodekar		3 tube set 2810.	

PRINCIPAL










HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	18/04/19	* Bacteriology Lab मरफिल		शिवकुमार व व्याप			
		वरचा विस्किला Plywood		भावासाहि दिनाम			
		वसतुन दिलो		कडन दिलो			
		* विदिना विडिंग 4 व 3		वांगारास पेट्टे ने			
		जा दंगळक कडन दिलो.		हे काम कडन दिलो			
		* जनरेट इयला मटलेला कनट					
		काडुन दिलो.					
		* Biochemistry Lab चा काटे		काटेवडेक वंगरीने			
		क्याल्लेया वंग सिनेडेया		काम कडन दिलो			
		कुकरेला विल लयाक करी					

PRINCIPAL





HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	18/04/19 *	Physiotherapy college HEL wooder corner मध्ये BSL ने सधेत करण होते	<i>Sushil</i>	निरीक्षण 21/5/19 21/5/19 ते करण ठेवले			
		विद्युत् त्रुटि 2, 3, 4, 7 8-9 अंश अंश अंश अंश अंश		अंश अंश अंश अंश दे करण ठेवले			
		जॉइंट होटेल 3 अंश 3-4	<i>Sushil</i>	निरीक्षण याने दे करण ठेवले			
		19. व 63 एम विद्युत् त्रुटि अंश अंश अंश अंश अंश		अंश अंश ठेवले			
	27/04/19 *	boys Hostel मधील अंश अंश अंश अंश अंश अंश		निरीक्षण याने दे करण ठेवले			
		होम मधील 16 अंश अंश अंश अंश	<i>Sushil</i>	अंश अंश अंश अंश दे करण ठेवले			
		Room No - 3-4-14 व 63 अंश अंश अंश अंश अंश		निरीक्षण याने व अंश अंश अंश अंश ठेवले			

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

*[Signature]*

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	24/05/19	इंटरव्हेंशन करून 62 पाठ्यात परीक्षा घेतली.					
		अगुणित: 57, 60, 6 (इंटरव्हेंशन)	<i>[Signature]</i>	मिनिमम कोमप्लायन्स	-	-	
		गुणवत्ता नियंत्रण आदेशांनुसार		अपडेट करून घेतली.			
		* इंटरव्हेंशन करून 71 मधील पाठ्यात					
		मिनिमम कोमप्लायन्स घेतली.					
		* मेलोडी :- वॉल 406 व 305		बिनाग्राम मिनिमम कोमप्लायन्स			
		वॉल 406 व 305 मधील	<i>[Signature]</i>	अपडेट करून घेतली.			
		दोन्ही वॉल मिनिमम कोमप्लायन्स मिनिमम कोमप्लायन्स					
		मिनिमम कोमप्लायन्स मिनिमम कोमप्लायन्स		मिनिमम कोमप्लायन्स मिनिमम कोमप्लायन्स			
		मिनिमम कोमप्लायन्स मिनिमम कोमप्लायन्स		मिनिमम कोमप्लायन्स मिनिमम कोमप्लायन्स			

PRINCIPAL

*[Signature]*



*[Signature]*




HEAD OF THE DEPARTMENT

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	27/05/2019	RMC Method and common Patient Method for Jethary and other part of asset.		originator signature date and asset.			
2)	28/05/2019	Anatomy Dept - Method of Jethary and Jethary and other part of asset.		Signature of Jethary 28/05/2019			
3)	30/5/2019	Pharmacology Method of Jethary and other part of asset. Computer Lab Method of Jethary and other part of asset.		Signature of Jethary IT Dept. Jethary 28/5/19.			

PRINCIPAL




HEAD OF THE DEPARTMENT

  
 DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	1/6/2019	DAMS class room मधील वाही मरली.					
		A principal मधील वाही मरली वर्गात वाही मरली आहे ही तक्रार मधील आहे.		वाही मधील वर्गात मरली आहे.			
27	14/6/2019	व्हाट्सअप ग्रुप मधील वाही मरली मरली आहे. ग्रुप मधील वाही मरली मरली आहे.		वाही मरली 01-29/6/2019			
37	15/6/19	वाही मरली मधील वाही मरली वाही मरली मधील वाही मरली आहे. मरली आहे.		वाही मरली मधील वाही मरली मधील वाही मरली मरली आहे.			

PRINCIPAL




HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	25/6/2019	NCI चे PG Inspection चौक गिरे. हीर Hospital माली faculty room हेर इतमोस ए मसुम हेर लिफ्ट मी अदरती श्री. अरिस्त येरान जिनाल अडल अरुन शीमली		अरिस्त येरान शीमली अरिस्त येरान शीमली			
		* A4 size paper शीमली देवली अरिस्त शीमली शीमली		शीमली देवली देवली शीमली			
		* अरिस्त शीमली अरिस्त अरिस्त अरिस्त		अरिस्त शीमली अरिस्त शीमली			
		अरिस्त अरिस्त अरिस्त अरिस्त अरिस्त		अरिस्त अरिस्त अरिस्त अरिस्त			

श्रीमती.

PRINCIPAL




HEAD OF THE DEPARTMENT






DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	7/7/2019	microbiology :- repairy of lampes for microscope in practical lab		by. Rishikesh on 17/7/2019		5 lamps.	
2)	7/07/19	repairy or/ replacement of coil in autoclave (Heating coil)		by Rishikesh on 07/7/2019		1 coil	
3)		microbiology :- No back up given by UPS kindly replace. the UPS		IT. Department Rishikesh		1 ups.	

PRINCIPAL





HEAD OF THE DEPARTMENT





DEAN



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	15/08/2019	Pathology :- Leakage of water cock pipe in bacteriology lab		सिरीस 21/8/2019			
		* Arrangement of projector in Demo - Room properly		IT Dept. 23/8/19			
		* Repair of microscope = labors in practical lab		सिरीस 23/8/19			
2)	03/8/2019	Library :- 20 tube circuit not working. Librarian office noted Exact Pen		by Alitesh mane 20/8/2019			
		* computer not working.		IT. Dept. survey.			
		6 nos of battery backup failed		on 21/8/2019.			

PRINCIPAL





HEAD OF THE DEPARTMENT





DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD


SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	04/09/2019	Biochemistry :- 3 distilled units not working.		by. Nilesh mane on 08/09/2019			
		* 2 Fan regulators Dept. library					
		* Professor :- start buttons of 2 computer keyboard of Professor room.			IT. Dept. mukund.		
2)	13/09/2019	Genetics lab :- tube light not working. Demo room :- 4 tube light & 3 fan not working. Blance room :- 3 tube light & 1 fan, 3 switch not working.		by Nilesh mane on 17/09/2019.			

PRINCIPAL





HEAD OF THE DEPARTMENT




DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1	23/09/19	Physiology :- Haemat :- 50 micro scopus servier, * 1 tube light & 2 fan not working.		by Nitesh mane Nitesh Oddekar & Nathuram Subale on 23/9/2019				
		* Phy. office 4 tube light 28W & 4 Switch buttons						
		APPMB. Lab :- 7 No. tube light & 24 nos switch						
		* Demo room :- 28W tube light, 1 switch						
		* Demo room 2 :- 2 tube light & Switch not working						

PRINCIPAL

*Handwritten signature*



HEAD OF THE DEPARTMENT





DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606


## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	8/10/2019	microbiology :- UPS for a. computer seat in HOD ROOM is not working Prob		IT Dept. Survey on 17/10/2019			
		Properly					
2)	13/10/2019	Pathology :- Histopathology unit 3 Switch Buttons, 1 Tubelight 3 Round LED Lamp.		by Nilesh mane on 26/10/2019		3 Switch 3 Round LED 1 Tubelight.	
3)	19/10/2019	Bone holder stand. under Unit not working					
4)	22/10/2019	Stand holder under unit		by Neelkamal Sankar on 24/10/2019		08W - Tube unit - 4 nos	

PRINCIPAL




HEAD OF THE DEPARTMENT




DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	27/10/2019	सुरक्षा विभागातील हार्ड वॉयस रूमची सुरक्षा तपासणी.	<u>Subale</u>	by Nathuram subale on 30/10/2019		6 tube set etc.	
2)	4/11/2019	लॉजिंग रूम विलीटिंग मॉड्यूल वॉयस रूम मध्ये मॉड्यूल त्रुटि व त्रुटि दुरु करणे.	<u>Subale</u>	by subale on 7/11/2019			
3)	11/11/2019	Anatomy Department:- Dissection hall, office, demo room Practical work stand of tube light & switch to fan must working	<u>Subale</u>	by subale on 20/11/2019 Replace & repairing			

PRINCIPAL

*R.M.*



HEAD OF THE DEPARTMENT




*P.S.*

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1	20/11/2019	Community medicine & Lecture Hall & heater light & Fan, & switch not working		by Nilesh mane on 16/11/2019	1203	2 Fan & light & tube set. & switch.		
2	21/12/2019	Pathology :- histo Lab out left pipe bracke inger grossing section passing and Anti room lounge			by Santosh sagwal on 15/12/2019			
3	16/12/2019	दिव्य लॉकर हेतु लाइट दिव्य लाइट दिव्य लॉकर हेतु लाइट दुरु लाइट.				by Nilesh mane on 27/12/2019		12W - 13 nos 09W - 5 nos 48 Bulb - 1 nos 112 Bulb - 1 nos

PRINCIPAL





HEAD OF THE DEPARTMENT





DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	23/12/2019	बिजली (ROOM NO-304) मरिज बिजली मरिज और गिड		बिजली मरिज 23/12/2019		1 बिजली 1 बिजली	
2)	23/12/2019	Anatomy: 2 Tube set. 5 switch, 3 Fan और दो 2 मरिज सुविधा मरिज XPSM office:- 1 फन 1 फन 2 Tube set 2 switch 1 फन 1 प्रोफेसर रूम HOD रूम, ऑफिस 2 गिडरूम रूम मरिज सुविधा 5 ट्यूब लाइट नॉट वर्किंग		by Akilash mane Hitesh Dodekar & alathuran Subbar on 20/12/2019			

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	7/1/2018	physiology Lab II need a fan 3 fanlight 2 of not working	<i>[Signature]</i> 7/1/18 Dr. N. N.	Replace & change <i>[Signature]</i> 7/1/18		28 W tubes 15 3 of 2 of	
2)	19/1/2018	microbiology media staff room media office, aseptic room, autoclave, library of HCP media tube not working	<i>[Signature]</i> 19/1/2018 Dr. N. N.	Replace <i>[Signature]</i> 21/1/2018		7 of 25 ml tube 15.	
3)	11/02/2018	Anatomy staff media light not working	<i>[Signature]</i> 11/2/18 Dr. N. N.	Replace & change <i>[Signature]</i> 14/2/18		36 W tubes 4 of 15.	
4)	17/02/2018	Anatomy - ventilation head media not working	<i>[Signature]</i>	Replace & change <i>[Signature]</i> 22/2/18		4 of 15 of 15.	
5)	3/3/2018	Pharmacology 51 & 58 media not working	<i>[Signature]</i> 17/3/18 Dr. N. N.	Replace <i>[Signature]</i> 17/3/18		7 of 15 of 15.	
6)	21/3/2018	microbiology - practical lab media not working	<i>[Signature]</i> 21/3/18 Dr. N. N.	Replace & change		13 tubes 25 ml.	

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

DEAN






B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	16/3/2018	Microbiology:- Binocular microscope Adapter with FLCB 37AMP 2nd of 5th floor.	 16/3/18	Replace 22/3/2018	2448	Adapter & FLCB Stamp.	
2)	20/3/2018	Library Physics Master room Master room with 2nd floor Master room with 2nd floor.	 20/3/18	Master room with 2nd floor Master room with 2nd floor.			
3)	20/3/2018	Boys hostel of girls hostel Master CCTV with 2nd floor Master room.	 20/3/2018	Master room with 2nd floor CCTV with 2nd floor.		CCTV - 3 nos.	
4)	13/4/2018	FMT Master room of common Toilet with 2nd floor.	 13/4/18	Master room with 2nd floor Master room with 2nd floor.			
5)	18/4/2018	FMT Master room of common Master room with 2nd floor.	 18/4/18	Replace 22/4/18		28W tube - 4 nos 40W tube - 6 nos 2nd floor - 12 nos.	

PRINCIPAL




HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
17	4/5/2018	Dissection hall :- ground water supply current water supply not proper ground water line	<p style="font-size: small;">K. Mahajan</p> <p style="font-size: small;">4/5/2018</p> <p style="font-size: small;">Peerly maintance with permission of chief Shri Mahajan Sir</p>	5/5/2018 to 7/5/2018 cur			66	
		office room - ground water supply * hall dose :- ground water line			Installation of tap water supply in ground water of rest.			
		Principle cabin :- Antise chamber ground of water ground water supply						
		Guests toilet :- ground water supply Ladies toilet :- ground water supply ground line.						
		Biochemistry office :- water supply ground line.						
		Pathology :- Blance room :- ground water cytopathology :- water supply water supply of ground water.						
		Histopathology :- water supply water supply ground.						

PRINCIPAL

*Signature*





*Signature*  
HEAD OF THE DEPARTMENT  
DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	31/05/18	Fmt :- toilet bathroom staff :- 2 nos 4 nos 12 inch pipe for drainage Pharmacology :- 4 nos 30ml kit office Clinical lab :- 4 nos 20ml kit office Museum :- 2 nos 10ml kit office Experiment lab :- 4 nos 20ml kit office Animal stimulation room :- 2 nos 10ml kit office Microbiology :- T, B lab :- 1 nos 10ml kit office Machine water circuit 1 nos Staff toilet :- 4 nos 10ml kit office	 R.V.S.S.	31/05/18 at 10:30 AM 4 nos water supply 2 nos 12 inch pipe 4 nos kit			
2)	31/05/18	Dissection hall :- boys washing Table with outlet pipe line zined. 12 inch pipe for drainage 12 inch pipe	 R.V.S.S.	12 inch pipe for drainage under drainage		12 Inch pipe.	
		12 inch pipe for drainage 12 inch pipe		12 inch pipe for drainage 12 inch pipe			

PRINCIPAL





  
 HEAD OF THE DEPARTMENT  
 DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	18/01/2018	Center Research Lab:- Aluminium water tap & water tap common Dilat :- Ladies :- T.B. Lab :- Distilled water plant	<i>[Signature]</i>	Water tap Distilled water plant		2 tap	
2)	15/01/2018	Pathology - histology	<i>[Signature]</i> 15/1/18	Replace 36W tube		36W tube	
3)	19/1/2018	Pharmacology Experiment Lab	<i>[Signature]</i> 19/1/18	Replace tube		4 tap	
4)	26/1/2018	pharmacology :-	<i>[Signature]</i> 26/1/18	<i>[Signature]</i>			

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT  
DEAN

*[Signature]*

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	31/06/2018	अर्थशास्त्राचे व मिली अर्थशास्त्राचे पुस्तके	शशिबाबा	20/6/2018 अर्थशास्त्राचे पुस्तके	1326		
		अर्थशास्त्राचे पुस्तके	31/6/18	अर्थशास्त्राचे पुस्तके			
2)	5/6/2018	Pathology:- 162, Anatomy:- 7, 12, 11;	शशिबाबा	P.N. & Saccarides			
	17, 40, 42, 46, Biochemistry- 128,	4/6/2018		4/6/2018 अर्थशास्त्राचे पुस्तके	1438	25 microscope stage	
	microbiology:- 246, 275, 283, 251, 270						
	Physiology:- 121, 117, 118, 64, 23, 100, 116, 70	25, 115, 119 microscope अर्थशास्त्राचे पुस्तके					
3)	14/06/2018	Common Pilot अर्थशास्त्राचे पुस्तके	शशिबाबा	अर्थशास्त्राचे पुस्तके			
	Jet spray अर्थशास्त्राचे पुस्तके	14/6/18		अर्थशास्त्राचे पुस्तके	1455	5 Jet spray	
	अर्थशास्त्राचे पुस्तके			अर्थशास्त्राचे पुस्तके		3 अर्थशास्त्राचे पुस्तके	
		अर्थशास्त्राचे पुस्तके					
4)	30/6/18	Library अर्थशास्त्राचे पुस्तके	शशिबाबा	अर्थशास्त्राचे पुस्तके	1475	1 Jet spray	
			30/6/18				

PRINCIPAL

*Signature*

STAMP



HEAD OF THE DEPARTMENT

DEAN

**B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE**  
**KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606**  
**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	4/07/2018	at college comical wall	[Signature]	विनाश करित		1 sheet used	
		महिला कक्षातील स्टार बोर्ड विसरले	[Signature]	4 कक्षातील स्टार बोर्ड विसरले			
2)	15/07/2018	AMT 22-24 मधील वॉटर	[Signature]	मिनी वॉटर मधील			
		विनाश करित	[Signature]	विनाश करित			
3)	20/7/2018	महिला कक्षातील वॉटर	[Signature]	मिनी वॉटर मधील			
		विनाश करित	[Signature]	विनाश करित			
4)	22/7/2018	कॅम्पस 212 मधील वॉटर	[Signature]	replace			
		विसरले	[Signature]	replace 24/7/2018			
5)	26/07/2018	कॅम्पस मधील 14963 कम मधून	[Signature]	मिनी वॉटर मधील			
		वॉटर विसरले करित	[Signature]	मिनी वॉटर विसरले करित			

PRINCIPAL

[Signature]

STAMP



HEAD OF THE DEPARTMENT







[Signature]

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	28/7/2018	m.c.s. and Anai Rajgiriya m.c.s. and Anai Rajgiriya	 28/7/18	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या			
2)	28/7/2018	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या	 28/7/18	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या			
3)	10/8/2018	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या	 10/8/18	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या		8W LED Tube 12W LED tube light.	
4)	10/8/2018	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या	 10/8/18	मि.स.स. व. अ. न. र. ज. ग. र. य. या मि.स.स. व. अ. न. र. ज. ग. र. य. या			
5)	12/8/2018	RMC office and not working	 12/8/18	Replace atubale		अ. न. र. ज. ग. र. य. या	
6)	23/8/2018	Animal house and not working	 23/8/18	Replace atubale		8W T. light	

PRINCIPAL



STAMP







HEAD OF THE DEPARTMENT

  
  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	2/9/2018	FMT. HOD point of water supply Biochemistry :- 1 line water supply not work.		विलोप विलोपित-सुध कारण प्राप्त करे.			
		Anatomy, Physiology of common point water supply not work.					
2)	17/9/2018	Library point of water supply not work.		विलोप विलोपित-सुध कारण प्राप्त करे.			
3)	23/9/2018	Library point of water supply not work.		Replace 25/9/2018		2841-5-415 6 2841-5-415 5	

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	2/10/2018	Pathology musions 2		Repair by mene		2, Capacitors	
		Fan Not working		on (3/10/28)			
	09/10/18	Pathology demo Rooms - 2 Tube pathology - lab - 1 Tube		Repair by Hidesh		5 - Tube 36V	
		Cordone square Tube - 3 not working		on (14/10/18)		3 square Tube	
	14/10/18	physiology HOD batrom		Repair by Hidesh			
		exas fan Not working					
	19/10/18	F.m.T. passage light					
		Not working		Repair on mene			
		* F.M.T. department office		Electer by (2/10/18)			
		Tube - not work					
		* HOD cabin door Repars		Repair by shikumar			

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	23/10/18	* विद्युत त्रुटि गळी दवाती मजग करी * वेगवेगळी त्रुटि गळी दखल घेवता		शिवायकुमार व लाम			
		* लाकडणी विल्लि S.V.S.C.T. सायकल पाकि मशीन उभार करी लाकडणी मशीन कोलोन मशीन practical job Remoiny * Steel ला वेळी मशीन		गणेशदास रेकाव घेवले			
		* Condor मशीन काम करी आहे व वीजला 2 हॅल - 2 मशीन कामात तशी गेली आहे		कार्यवाही यंत्रणेकडून रेकाव घेतली			
	19/12/18	* त्रुटिदखल घेवता करी मशीन तुळती को. ला मशीन		कार्यवाही यंत्रणेकडून घेतली			
		* F.M.T 2 floor ला पाणी येत आहे		संशोधन मशीन मशीन मशीन घेतली			
		* हेलीकॉप्टर 10 मशीन व लाकडणी मशीन मशीन मशीन मशीन मशीन मशीन		शिवायकुमार व लाम मशीन			
		* मशीन मशीन मशीन		रेकाव घेतली			

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	02/12/18	कोलेजमधील हंगु सेटअप मध्ये काही दिवसात काही एलएलसी		विजेतय सागरत सांगी हे काळ घ्यावे			
		* लोकांक एलएलसी 1, 2, 3, 4 साठी निवडलेले साठी 2000 रुपये काळ घ्यावे		शिस्तुकार काळ घ्यावे			
	05/12/18	* लोकांक एलएलसी - 3 साठी 5000 रुपये					
		अभियंता कार्यालय दिवसात साडे 8 मधून साडे 4-40 व विजेची पुनर्स्थापना करणे किंवा 5000		काळ घ्यावे			
		* Common Toilet ची सांडखोल साठी पुनर्स्थापना		पुनर्स्थापना करावे			
				20000 रुपये काळ घ्यावे			

PRINCIPAL




HEAD OF THE DEPARTMENT






DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	12/01/17	boichemsky gas burner lifera	 12/11	Repair by gangadhar Gangadhar, S. M. Kulkarni ent. pune 23/01/2017	—	Celcon tube	-
2)	22/01/17	NEK mic Not working Lecture Theater No - 3	 22/1/17	Repair by yatin Kulkarni (14th) on (02/02/17)	—	—	—
3)	14/02/17	reaction murchani cabinet No - 2 cooling coil मरुचणी काबिनेट - 2 का कूलिंग कोइल	 14/2/17	Repair cooling coil by Top coll. eng Nare Aziz (pune) on (28/02/2017) Aziz eng No - 9326012812	—	—	—
4)	04/03/17	Lecture theater. No - 3 model mic Not work model MU53L	 4/3/17	Repair by yatin Kulkarni (10/03/17)	—	—	—
5)	19/04/17	Bots Hostel. C. Hostal 7 Library मॉडेल A.C. मॉडेल ESCB. Base on मोडेल मॉडेल		मॉडेल मॉडेल 3 मॉडेल मॉडेल			

PRINCIPAL



STAMP



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	22/04/17	दोहे नसिमि गरी खीर जाला २०० मिळी १०० मिळी	<i>[Signature]</i>	Replace by Noshim sable on (24/04/17)	947	brush	25
2)	25/1/17	Revolving stool damaged.	<i>[Signature]</i>				
		1) Dissection Hall - 3 Tabel	<i>[Signature]</i>	Repair by Rom			
		2) Hist. lab. 2 Tabel					
		3) Physiology clinical - 5 Tabel		sewak on			
		4) Heartlab - 3 stool		02/06/2017)			
		5) beichert 2 stool					
		6) Fmt - practical lab - 2 stool		<i>[Signature]</i>			
		7) Psm - music - 3 stool		25/5/17			
		8) pathology lab - 5 stool					
		9) Pharmac practical lab - 2 stool					
		10) microbiology - 5 stool					

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*

*[Signature]*


DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
6)	13/04/17	Pathology department नहीत Ante room नहीत File कालेपनी मीसो वर लागू होत न Plastic Hand वापर होत		मैसिन वापर होत न संशुद्धी 72% अल्कोहल व साधन वापर होत न (12/04/17)	-		Inward No <u>23</u>	
9)	13/04/17	Principal चीम नहीत अंतर्गत सिमेंट मी मीसो वर होत न होत व रीम लागू होत न		-	कांता व लायन मीसो वर होत न (16/04/17)	-		<u>24</u>
4)	13/04/17	21/3, 20/3 नहीत कॉमन टॉयल बेड मी ग्लास व डबल वॉशिंग मी न Expositon जोत न केवळ होत न		-	मैसिन व साधन वापर होत न (15/04/17)	-		<u>24</u>
1)	13/04/17	Common room मी Sky light कालेपनी गुणवत्ता मीसो वर होत न		-	मैसिन व साधन वापर होत न (13/04/17)	-		
7)	13/04/17	कांता व लायन मी मीसो वर होत न व रीम लागू होत न		-	मैसिन व साधन वापर होत न (13/04/17)	-		<u>25</u>


PRINCIPAL



STAMP



HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	13/07/17	मेडिकल कॉलेज मध्ये सुधारणेसाठी आवश्यक असलेल्या मध्य मजलीसची गरजा मी ११५६८ खर्चासाठी खर्च करीत आहे तसेच ११६००		संशोधन मजलीस मध्ये काम करीत आहे.	-	नवो वॉटर	-
2)	10/08/17	मेडिकल कॉलेज मधील Toilet + bath मधील 2 exact fan खर्चासाठी ५००० खर्च करीत आहे	R. Shikari	मेने वहीतले मंजुरी ते नाम घरी करी 15/08/17	-	2 exact fan	
3)	15/08/17	Rural medical college Omsalale Dept. has not working S.R. No - 1130306940	R. Shikari	Repair by Yatin Kulkarni (1111) 9379 004 477 (25/08/17)	-	-	-
4)	19/10/17	Sport Academy Clubmily local मध्ये मध्य मजलीसची गरजा मी ११५६८ खर्चासाठी खर्च करीत आहे तसेच ११६००	R. Shikari	ते सुधारण करणे दिले (25/10/17)	-	-	01
5)	23/11/17	Biochemistry demo Room cher- 13 set - 11 set - 1 - 11 set - 1 - 5 cher 23 - 4 Cher	R. Shikari	फिफ्टी मॅट्रान १ २१०० खर्चासाठी			

PRINCIPAL

*[Handwritten Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Handwritten Signature]*

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
3)	23/11/17	1) Pathology museum - 6 chair 2) Anatomy museum - 6 chair	<div style="border-left: 1px solid black; border-right: 1px solid black; border-bottom: 1px solid black; padding: 5px;">                     B.K.L. Walawalkar 23/11/17                 </div>					
		3) pathology demo - 4 chair 4) P.J.M. demo - 4 chair			दिनेश मेहता व			
		5) F.M.T. demo - 6 chair			राधा मेहता या			
		6) Pharmce demo - 5 chair			विनयकुमार - प्रमसाकी			
		7) Animal simulation - 7 chair 8) micro demo - 6 chair			लेकाड पुर्णि केले	-	-	
		9) Animal House car mask A basket Filing						
		10) J Hook hanger for Hanging Gun						
		11) Pharmic HOD cabin door fan						
		12) A.P.R. Room door Repairing						
		13) Tutor Room Door Repair						
		14) Proffesa Room door Repair						
		15) Pharmce office Room door Repair						

PRINCIPAL



STAMP



HEAD OF THE DEPARTMENT



DEAN

B.K.L. Walawalkar Rural Medical College  
At, Kasarwadi, Post, Sawarde  
Tal, Chiplun, Dist, Ratnagiri



# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	24/10/17	Boys Hostel 1) C.C.T.V. Board fitting	<div style="border: 1px solid black; padding: 5px; display: inline-block;">                     24/10/17                 </div>					
		2) zelam 4. Irruak' builds 2 NOS			दिनेश व राधा	—	—	—
		Girls Hostel/ D.C.C.T.V board fitting			हेमंत शिंदे			
		3) Arank ① f ② - 2 NOS			काज शिंदे			
		* 1) Pathology - Balance Room Door Repair -						
		2) Cytopathology - Door repair						
		3) Washing Room - Door Repair						
		4) Report Room - Door Repair						
		* Patho - Amid-Door screws - Hinges + some fittings						
		Patho - Door - Door Repair						
		Patho - Corridor screw fitting						

PRINCIPAL



STAMP



HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	23/10/17	Anatomy - Desrefin Hall Tube Light 2 eyes 1	}	Replace by			
		* Histolab - Tube - 1					
		* museum - Tube 1					
		* microscope - 2 service					
		* Demo - 1 Tubelight 3					
		* offica Tube - 1					
		* Library - 2 Tube					
		* Tubora - 1 Tube					
		* museum - microscope service - 21		Service by Abishek Rohate			
		* histolab pipe litore		Repair by santer sewal -			
		* physio - Departmental Hermit					
	23/10/17	lab - 59. microscope 2 service		Service by Rohate Abishek			
		* Hermit - I Tubelight Amphibia 2 Fan, 0		Replac by Mene			
		* offic - Tube 4		electrician on (21/10/17)			

PRINCIPAL




HEAD OF THE DEPARTMENT



DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR .NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	23/10/17	Door Room - 2 - Tadipatti sarees Fibres					
		* practical lab - Tadipatti sarees fibres mythology	}	दिनेश व राधा प्रेरक			
		* Non Textiles - sarees fibres		यांनी हे प्लाग खेले.			
		* Assit prof. Frame growing					
		* <u>Antibody</u> - Corridor and main door sarees fibres					
		* Clerk Room - Door fibres Library cum junior room - door Repair					
		* Dissection Hall door fibres					
		* central block M.E.U - door Repair					
		* Hall No 57 Door Repair					
		* Animal House Door Repair					
		* 21 No - Door Repair					

PRINCIPAL

*Signature*



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
*		P.S.M. Department					
	02/05/17	Practical lab - Tower fitting Museum - Tower belt fitting Lecture Theater - Tower bolt	}	दिनेश क राणा			
*	pharmacology - Museum - Tower bolt & Resin Clinical Formae - main door experiment - Tower bolt Pharmae - Toilet stoper	प्रेसमी चानि कपि - किले					
*	F.M.T 1) Examination Hall. All door Screen fitting 2) Museum - Tailor patch fitting 3) practical lab - Tower bolt 4) Non Techno - Tailor patch fitting						
*	Microbiology - 1) Duroo Room - Door Repair						

PRINCIPAL




HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	25/10/17	* Physiology * Clinical lab; Heamok lab * Information lab - door Repair	}				
		* department officed on N. Pedson Repairing			दिनेश केरकरि		
		* Biochemtry * main dar - lab main dar Office main dar. library dar * shop room - glass Fibre			व राण केरकरि		
		* Praddegarum - sam fitus			वाण के काय केत		
		* - - - - - door Repair of Stages					
		* Assit Bm - door Repair					
		* Room No 26 - Stages Repair					
		* Main dar. Repair					
		* <u>Ceiling</u> HO Steel					
		* Avanti, 1 & 2 Notice board Fibry					

PRINCIPAL

*[Handwritten signature]*



HEAD OF THE DEPARTMENT

*[Handwritten signature]*  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
	28/10/17	Dorm Room patching Tab-1 ↳ Muriatn. small plug of epoxy with box	}	Replca by Hitesh dudhkar - on 28/10/17			
		↳ Hemmat lab, 27,28,50,54,56 Tube Net work					
		↳ 152 room No. Tube Net work Net - 2					
	28/10/17	Biochemis. practical lab 3 dimert distillation unit not working	}	Repair by Hitesh on - 28/10/17			
		↳ 2 Fans Regulation Net work					
		↳ pharam corridor ↑ Tube Net working			Replace by Meme on 28/10/17		
		↳ Library buildig Tube - 20 Nos Switch - 4 Nos Eros - 1 Nos		Repair by Hitesh 28/10/17			

PRINCIPAL




HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1	14/11/2017	L.E.D. Drivers - 9 Nos D. Principle cabin - 6 Nos		Repair by L.E.D Light f. driver by Sruve electron on	1	L.E.D - 10 Nos Driver - 10 Nos	
		2) college council T. Centre 2 Nos 3) 10 - Nos 4) Corridor mouse - 10 Nos		22/11/2017		D. DSRM - 3 Nos 10 Nos 4 Nos 5) S.M.D LED Tubelight - 5 Nos	
		5) Microbiology practical lab. - 5 Nos					
	15/11/17	P.S.M. Demo Room CH Not working		Replace by Soble on 16/11/2017 <del>Sobale</del>	-	1 CFL (12 V)	
	16/11/17	Microbiology A.V lamp Not working demo room Tube Not working f. mouse Tube Not work		Replace by mouse electron		A.V lab. - 1 Tube - 4 (220V)	
		lab corridor 1 Tub damaged Not workh practical lab microb servia		Service by Abhin Rabor			

PRINCIPAL

*[Signature]*



HEAD OF THE DEPARTMENT

*[Signature]*

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	26/11/2017	Library tube series not working properly		Replace by man on 26/11/2017		25W tube - 43001	
2)	30/11/2017	Library :- 6 computer & 29 battery backup not working		Repairing for IT department by suraj on 31/11/2017		Microscope - 24001 Reflector - 24001	
3)	4/12/2017	Pharmacology not - Antivirus to all computers update		Install antivirus by suraj on 11/12/17			
4)	7/12/2017	microbiology - Repair of lamps for microscope in practical lab		Replace by Rahate on 31/12/2017		5 Lamps	
		repair of/ replacement of coil in autoclave room (Heating coil)		Replace by suraj on 14/12/2017		2 coil (15000v)	

PRINCIPAL

*Suraj*



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri



# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	15/12/2017	Leakage of water - cock pipe in pathology Lab		Repair by Santosh sejawal			
		* microbiology :- door lock. Amusement old Archib door Room		I.T. deratmeh by suraj			
		* Replace of microscope lens in Basical lab		Repair by Abishale Rabate		3 lamr.	
	12/11/17	F.M.7 printer - Keys C.L.L not working		Repair by messe	-	1. cell	
	21/12/17	Lecture theater No-3 door Repairing & Corridor square light not working		Repair by shivra & more lab			
	09/12/17	Common Toilet Bathroom		Repair by			
		cock Not work.		sejawal			

PRINCIPAL

*[Signature]*



*[Signature]*  
HEAD OF THE DEPARTMENT  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	02/01/2016	Physiology department HOD cabin square Light Not working	<i>[Signature]</i>	Replace new square Light on (02/01/2016)	132	—	
2)	09/10/2016	Physiology Passage 36 wt Tube light Not working (3 NOS)	<i>[Signature]</i>	Replone New 36wt Tube on (12/01/2016)	136		
3)	16/01/2016	Biochemistry Research lab Fan Not working (1 Nos)	<i>[Signature]</i>	Reident 3 Nos Fan by (700ah electronic square)	—	—	
4)	21/01/2016	department of physiology department + office 3 switch Not working.	<i>[Signature]</i>	Replace a New 2 switch on (22/01/2016)	164	—	
5)	28/01/2016	department of Anatomy passage square light Not working (4 NOS)	<i>[Signature]</i>	Replace New square fish by proful. Sure of postheromg eletical	—	45 web New square light	—
6)	29/01/2016	1) department of Physiology clinical lab 2 fan not work 2) department of physics & tube Not working	<i>[Signature]</i>	Replac 1 capacitor by fashelctrc R New Tube on (30/01/16)			—

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	01/02/2016	Heatmetology lab basin Coat Not working	<i>P. Shinde</i> 11/2/16	Replance by New Coat on (03/02/16)	162	1 No Coat	-
2)	10/02/16	ANOTHY H.P.D bathrooms Jet spray Not working.	<i>P. Shinde</i> 10/2/16	Replace a new Jet spray on (14/02/16)	165	1 Jet spray	-
3)	12/02/16	1) common ledge toilet Jet spray Not working	<i>P. Shinde</i> 12/2/16	1) Replance by a Jet spray New	176	1 Jet spray	
		2) common bathroom 3 cock Not work		2) 3 cock New		3 cock	
4)	15/02/16	Physiology Heatmet lab 16. mp. point Not working.	<i>P. Shinde</i> 15/2/16	Replace new 16 mpa by (pushworn & kormator on (27/02/15)			
5)	28/02/16	departmental oltia pc Not working	<i>P. Shinde</i> 28/2/16	Replance by I.T. department on (01/03/16)			

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	04/03/16	C.C.T.V. camera Not working.	<i>[Signature]</i>	Replace by Amit gasavi (panni)	—	New camera	—
2)	10/03/16	H.O.D. cabin का दरवाजा की बंदगी ठीक करवायी.	<i>[Signature]</i>	दरवाजा के बंदगी ठीक करवायी 10/03/16	—	1. बंदी	—
3)	19/03/16	Lecture hall No. 1 Laptop power cord N. HDMI cable not working	<i>[Signature]</i> 19/3/16	Replance new power cord A HDMI by IT. department	—	New power cord A HDMI	—
4)	24/03/16	pharmacology लेब में बंदी का ठीक करवायी.	<i>[Signature]</i> 24/3/16	बंदी के ठीक करवायी 24/3/16	—	—	—
5)	16/04/16	pathology HOD cabin Fan Not working	<i>[Signature]</i>	Repale. New capacitor by Amn!	—	—	—
6)							

PRINCIPAL

*[Handwritten initials]*

STAMP



HEAD OF THE DEPARTMENT


*[Handwritten signature]*

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO	
1)	16/04/2016	Following practical lab 22=water Tubs are not working some tubs are broken	 Dr. Shivraj 16/4/16	Replace all				
				New 22 Tubes				57
		1) D.F.M.T practical 5 Nos		by Ka. Harish				58
		2) morbid anatomy/cyts lab-2		Ka. Somkar on				
		3) Clinical patho - 2 Nos		28/04/16				
		4) experimental <sup>micro</sup> patho. - 4 Nos		12/07/2016				
		5) micro practical lab - 2 Nos						
		6) Bacteriology - 1 Nos						
		7) physiology - 6 Nos						
		Total - <u>22 NOS</u>						

PRINCIPAL



STAMP



HEAD OF THE DEPARTMENT



DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	05/05/2016	मेडिकल कॉलेजमधील सर्व बाळकी दरवाजे 216 नंग व ल्यांश कड्या पडती व लाळकी St-pan लसवुन मिळणे		14/05/16 To 17/05/16 21 बाळकीपधिल शिवकुंक या मागसाधी सर्व दरवाजे कुकळ करी दिले.	-	-	-
2)	10/05/16	सर्व कॅम्प पुस्तकालय लेन फॉल कॅम्पुगियम दारा आली कुकळ करीत. त इडस करुन मिळवणे.		13/05/16 व 14/05/16 कॅम्पुगियम कॅम्पुने सि काठ करु दिले	-	door handle 4 Nos Hinges - 6 Nos	-
3)	14/05/16	मेडिकल कॉलेज मधील लाळ्या हवेचे फुडुन वरती आल्या काटेत त्या लसवुन देणे		17/05/16 माग करु काठ पुन आले.	-	-	-
4)	03/06/16	ground floor corridor square light not working 6 Nos		Replace 6 New Check by (09/06/16)	-	6 New clock	-
5)	13/06/16	Boys corner Room 3 switch Not working		Reales. new switch 3 GEH. And 1 3gw wat. Tub Light. ON 15/06/2016	1003.	3 switch. And Tub Rod	-

PRINCIPAL

STAMP



HEAD OF THE DEPARTMENT

DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
6.	10/07/16	KARCHER machine. Not working.	<i>[Signature]</i> Suction Net Dorkey	Suction. moter. Replec on 20/07/16 By ingenire. Ratnagiri.	11040	suction. moter.	
7.	14/07/16	water. bath. not working In. clinicale. Pharmacology Lab.	<i>[Signature]</i>	Replece new 250w @ coil.	1204.	250 w Coil	
8.	22/07/16	Theyr. is swort swarkit. Auto claw Room in. microBiology. Department	<i>[Signature]</i> Short circuit mcb was Fopped in Autoclave <i>[Signature]</i>	Correct. Replece new 36w m.c.B. in. Autoclav Room	in stock.	36 w M.C.B	

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*

DEAN

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
9	31/08/16	सर्व प्रयोगशाळा वॉटर मशीन डिस्क्रीट कॉलेज वॉटरचे पाइप व वॉल वॉराव मीले अडित.	Dr. N. D. Karmali	Repace 26 Rubber Pipe. 13 Tab by Santosh. sejewal. on. 15/8/16.		12.m Rubber pipe and 811 tab gm -cut	
10	17/09/16	Anatomy department over. Head projector. not working	Dr. B. B. Bhat	Replaced 12 Hold bulb And power swich. 18/09/16.		12 Hold bulb P And. Power swich.	
11	5/10/16	Lecture theatre No 2. Head. neck micke Not working.	Dr. B. B. Bhat	Repaired by yatin. kulkarni Pune. on. 25/10/16			
12	5/10/16	PSM. Department Room No -116, 116, 118, 120 चे दरवाजे कुठारा अडित देणे रिसेप्ट Demo Room चा 8 अडित कुठारा अडित देणे.	Dr. Shrinani	दिवकुमार चा मीले ऑ. वॉराव कुठारा अडित रीट a Demo. Room चा अडित. TOP कुठारा अडित देणे.		8 plowood TOP	65.

PRINCIPAL

STAMP



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri



**B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE**  
**KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606**  
**FORMAT FOR MAINTANANCE NC RECORD**

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
13)	13/10/16	अभ्यास सिलेबस 9 रूम वॉटर कनेक्शन मरुत एवढे साठी.	Rishikay 13/10/16 SP. N	Replace 12 in x 1/2 2 Nos & 24 in x 1/2 by same electrician on 17/10/16	1356	exos-12 in - 2 24 in - 2	
14)	11/12/16	North block comon toilet bathroom check up.	Rishikay 11/12/16	Repair by Santosh Patil 12/12/16	—	—	—
15)	28/12/16	Clinical pharmacology & eximent pharmacy 1st floor distild water plant 200 & 400m	SP. N	Replace 250 wt by mone.	—	250 wt cell	—
16)	28/12/16	Room Boys Hostel Room No. 37 Tube light & Room No - 25 - fan cord	SP. N 23/12/16	Replace by mone & Hidesh SP. N	—	Tube - No. 1 Copper - I	

PRINCIPAL

*(Signature)*

STAMP



HEAD OF THE DEPARTMENT

*(Signature)*

DEAN

B.K.L. Walawalkar Rural Medical College  
 Al. Kasarwadi, Post. Sawarde  
 Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR. NO	DATE	NC DISCRIPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	6/01/2015	Lecture Theater No-2 Fan Not working. <del>(13)</del> Total - 13 Nos	<i>[Signature]</i> 6/1/15	10 <del>11</del> fans Reinded And three fans Replase capacitor 17/01/2015 by <i>[Signature]</i> Tash electricals (Sawarde)	Get post No <u>830</u> 145. pm	3 capacitors	Letter No 9
20	07/1/2015	College Councill Hall. 5wt spot light Not working	<i>[Signature]</i> 7/1/2015 <i>[Signature]</i>	Replace 5wt New Spot light by pradull surve & parshuram electric on 19/1/2015	<u>832</u>	5wt spot light bulb	10
3)	07/1/2015	pricipal cabin 7wt spot lish 5wt	<i>[Signature]</i>	Replace 5wt as above			

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*






DEAN

B.K.L. Walawalkar Rural Medical College  
Al. Kasarwadi, Post. Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	15/01/2015	Physiology department mechanism lab. cap. Flow meter not working		Repair by kashinath Charan (16/01/2015)	—	Rubber vison	—
2)	18/01/2015	Caston Rod. Fullt. down in Lecture Theatre No.2 window No. 5 & 4		corrective action taken 18/01/2015 by Shivkumar.	—	2 screws	—
3)	19/01/2015	<u>College Council Hall</u> 1) spot light R.L. 6 watt not working. (2 Nos) 2) door lock not working 3) Active LED. Panel LED Light 22 watt 4) principal cabin door close set not working		Replace 3 6 watt R.L on (22/01/2015) door lock replaced on (22/01/2015) Replace by pradull sume on (22/01/2015)	— — —	1. R.L 6 watt 1. LED panel door set	— — —
4)	24/02/15	Photography unit computer not working		Repair by I. T dept on (22/01/2015)	—	—	—
5)	05/05/2015	Stairs Not working in Reception Hall. Anatomy		Repair by yash etc (source)	Get pass No 876	—	28

PRINCIPAL



STAMP



HEAD OF THE DEPARTMENT

DEAN

B.K.L. Walawalkar Rural Medical College  
At Kasarwadi, Post Sawarde  
Tal. Chiplun, Dist. Ratnagiri

# B.K.L. WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCRPTION	RECORDED BY	CORRECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
1)	23/06/15	P.F.T methu Not working in physiology dept	<i>[Signature]</i> 23/6	Replac New Fuse and power cable. by sangan electronic on 30/06/2015	472	1) Fuse 2) power cord	-
2)	04/07/15	Physiology HOD Room AC split AC Not working	<i>[Signature]</i> 4/7/15	Replac New coil kit by. prithal singh Team on (17/07/15	-	1) coil kit	-
3)	13/08/15	Pharmacology, museum & microbiology museum educational charts Frame bot Total 10 Nos	<i>[Signature]</i> 13/8/15	Replac New wooden Frame. (19/08/15		Wooden frame 10(Nos)	-
4)	22/09/15	P.S.M. HOD chair wheel brake	<i>[Signature]</i> 22/9	Replac by Nitin (hip) shinde (25/09/15)		wheel 3 nos we	
5)	29/09/15	college counsil Hall. cond ler) mic not working.	<i>[Signature]</i> 29/9/15	Repair by yotik kulkarni (PNC) on (10/10/15	Get pass No. 887	New power button.	
6)	29/10/15	F.M.F Busch job 15 mr. point Required for that plate water bath slide working table	<i>[Signature]</i> 29/10/15	Replac new 15 mr point by (Pardham & Karmakar) on (31/10/15)	-		48

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*  
DEAN

# B.K.L.WALAWALKAR RURAL MEDICAL COLLEGE

KASARWADI, POST SAWARDE, TAL CHIPLUN, DIST RATNAGIRI PIN 415 606

## FORMAT FOR MAINTANANCE NC RECORD

SR.NO	DATE	NC DISCIPTION	RECORDED BY	CORERECTIVE ACTION TAKEN DATE & SIGN	REQ. NO. (INDENT NO)	MATERIAL USED	INWARD NO
17	3/11/15	Lecture Theater No - I micro-Amplifier not working	<i>[Signature]</i> 11/15	Replaced by <i>[Signature]</i> Kulakum-puram (02/11/15)	—	—	50
20	27/11/15	COMon Toilet bathroom 2 jet spray not working	<i>[Signature]</i> 23/11/15	Replace by. Santosh Sagarai on (04/12/15)	<u>382</u>	2 Jet spray New	

PRINCIPAL

*[Signature]*

STAMP



HEAD OF THE DEPARTMENT

*[Signature]*  
DEAN

## NON COMPLIANCE RECORD

### MICROBIOLOGY LABORATORY




SR. NO.	DATE	COMPLAINTS	CONCERN DEPARTMENT SIGNATURE	CORRECTIVE ACTION
5	9/2/15	UPS sounds different & fails to supply.	<u>GAN</u> 9/2/15	<u>[Signature]</u> 19/02/15
				Cooling fan changed
6.	2/1/15	centrifuge not working	Carbon brush changes.	<u>[Signature]</u> 02/07/15

[Signature]

[Signature]  
DEAN

# NON COMPLIANCE RECORD

## MICROBIOLOGY LABORATORY

SR. NO.	DATE	COMPLAINTS	CONCERN DEPARTMENT SIGNATURE	CORRECTIVE ACTION
1	16/11/14	weighing machine is not working.	the battery replaced	
2.	27/11/14	Heighting Balance is not working	UPS battery replaced inform to contractor weighing machine company for problem in charger section. 02232459901	 16/11/2014
3.	2/11/14	phone not working for 24 hrs.	phone repair योग-राज-केसरी	 3/11/14
4.	14/10/14	Centrifuge not working	Carbon brush change.	 14/10/14 DEAN

# NON COMPLIANCE RECORD

## MICROBIOLOGY LABORATORY

SR. NO.	DATE	COMPLAINTS	CONCERN DEPARTMENT SIGNATURE	CORRECTIVE ACTION
17				
18	31/7/2013	Autoclave kettle connector spools		<i>[Signature]</i> 31/7/2013
	31/7/2013	Hot air oven problem. (Thermostat problem)		
19	10/8/13.	weighing Balance not working		
20	18/8/13	(UPS problem)		change ups battery
21	06/12/13	(Incubator) mase & ups problem.		<i>[Signature]</i> 18/8/13
22	22/12/13	Incubator temp from 37° rise to 100° suddenly		<i>[Signature]</i> Call electrician, mo-Gangan.
23	28/12/13	Thermostat changes by eng (newgun part) <i>[Signature]</i>		
23	16/1/14			
		<i>[Signature]</i>		

*[Signature]*  
DEAN



# NON COMPLIANCE RECORD

## MICROBIOLOGY LABORATORY

SR. NO.	DATE	COMPLAINTS	CONCERN DEPARTMENT SIGNATURE	CORRECTIVE ACTION
1	16/11/2011	Non availability of computer & printer		Provided computer
2	19/04/2012	Non availability of phone connection	फोन वाइरिंग का आरंभ श्री. योगेश शर्मा	Provided phone connection
3	19/04/2012	Non availability of Palck software		
4	19/04/2012	Non availability of door closer for door of testing lab-2		Provided door closer
5	12/07/2012	Non availability of exhaust fan in testing lab-2		
6	12/07/2012	Non availability of cabinet for 200 cylinder placed outside.		
7	23/08/2012	Autoclave not working properly.		Autoclave replaced.
8	10/10/2012	freezer compartment temp. of domestic fridge is not maintained below 0°C.		Domestic fridge repaired.
9	20/03/2013	Non availability of chopras patti to 7-cupboards in lab.		Chopras patti provide.
10	20/3/2013	To repair door of the media preparation room & testing lab room.		Doors repaired.
11	21/3/2013	Handle of the table untined		Handle repaired.
12	01/3/2013	A.C. in Bacter room is not working properly. cooling temp. not maintained.		A.c. repaired. 02/13/13.
13	04/05/2013	Incubator temp rises automatically above 100°C		
14	31/5/13	Autoclave connect wire sparking.		wire repaired 31/5/13.
15	4/6/13	Autoclave wire sparking & off		wire repaired 4/6/13 DEAN
16	4/6/13	Laminare air flow's electric current connect off. disconnect		M.C.B. Tri 4/6/13 B.K.L. Wairavkar Rural Medical College Alkasanwadi, Post-Saverde Tal. Chiplun, Dist. Ratnagiri